Explanatory document to the Common Coordinated Capacity Calculation Methodology for Capacity Calculation Region Hansa in accordance with Article 20(2) of Commission Regulation (EU) 2015/1222 of 24 July 2015 establishing a Guideline on Capacity Allocation and Congestion Management

~~10th Apri~~October ~~I~~ 202~~6~~5

Til arbejdsbrug/Restricted

Abbreviations:

AAC	Already Allocated and nominated Capacity
AC	Alternating Current
AHC	Advanced Hybrid Coupling
ATC	Available Transfer Capacity
CA	Capacity Allocation
CACM	Capacity Allocation and Congestion Management
CC	Capacity Calculation
CCM	Capacity Calculation Methodology
CCR	Capacity Calculation Region
CGM	Common Grid Model
CNE	Critical Network Element
CNEC	Critical Network Element Contingency
CNTC	Coordinated Net Transmission Capacity
DA	Day Ahead
DC	Direct Current
FB	Flow-Based
GSK	Generation Shift Key
ID	Intraday
IGM	Individual Grid Model
NEMO	Nominated Electricity Market Operator
NTC	Net Transfer Capacity
NP	Net Position
OWF	Offshore Wind Farm
PTDF	Power Transfer Distribution Factor
RA	Remedial Action
TRM	Transmission Reliability Margin
TSO	Transmission System Operator
TTC	Total Transfer Capacity
XBID	Single intraday market coupling

Til arbejdsbrug/Restricted

Table of Contents

1.Introduction **5**

2.Legal requirements **6**

3.Definition of bidding-zone borders in CCR Hansa **9**
3.1 Description of the Denmark 1 – Germany/Luxembourg AC border 10
3.2 Description of Kriegers Flak Combined Grid Solution 11

4.Capacity calculation methodology for the day-ahead time frame **14**
4.1 Rules for calculating cross-zonal capacity 14
4.2 Description of the capacity calculation methodology in CCR Hansa 14
4.2.1.Mathematical description of the applied approach 17
4.2.2 Capacity limitations originating from the AC grid handled by AHC in CCR Nordic 19
4.2.3. Capacity limitations originating from the AC grid handled by AHC in CCR Core 20
4.2.4. Further requirements from Article 21(1)(b) of the CACM Regulation 21
4.3 Methodology for determining the Transmission Reliability Margin 22
4.4 Methodologies for determining operational security limits, contingencies relevant to capacity calculation and allocation constraints 24
4.5 Methodology for determining the generation shift keys 29
4.6 Methodology for determining remedial actions to be considered in capacity calculation 29
4.6.1 Remedial actions to maintain anticipated market outcome on KF CGS 31
4.7 Rules for taking into account previously allocated cross-zonal capacity in the day-ahead time frame 31
4.8 Fallback procedure for day-ahead capacity calculation 31

5 Capacity calculation methodology for the intraday time frame **32**
5.1 Description of the capacity calculation methodology in CCR Hansa 32
5.1.1 Capacity limitations originating from adjacent AC grid 32
5.1.2 Further requirements from Article 21(1)(b) of the CACM Regulation 32
5.2 Methodology for determining the Transmission Reliability Margin 33
5.3 Methodologies for determining operational security limits, contingencies relevant to capacity calculation and allocation constraints 33
5.4 Methodology for determining the generation shift keys 33
5.5 Methodology for determining remedial actions to be considered in capacity calculation 33
5.6 Rules for taking into account previously allocated cross-zonal capacity in the intraday time frame 33
5.7 Intraday reassessment frequency 33
5.8 Fallback procedure for intraday capacity calculation 34

6.Common Provisions Applicable to both the Day-Ahead and Intraday Time Frames **35**
6.1 Methodology for the validation of the cross-zonal capacity 35
6.2 Monitoring data to the national regulatory authorities 36
6.3 Publication of data 36

7.Evaluation of the CCM in light of the objectives of the CACM Regulation **37**

8. Implementation plan **38**

Til arbejdsbrug/Restricted

Annex 1: Justification of usage and methodology for calculation of allocation constraints in PSE 41

Annex 2: Advanced Hybrid Coupling (AHC) – a Short Explanation 47

Annex 3: Explanation on a temporary exception for the DA and ID capacity calculation for DE/LU-SE4 (Baltic Cable) to account for the local DSO grid topology on DE side 51

Til arbejdsbrug/Restricted

1. Introduction

This document contains explanations for the proposal for a common coordinated capacity calculation methodology for the day-ahead and intraday time frame for the capacity calculation region of Hansa (CCR Hansa) in accordance with Article 20(2) of the Commission Regulation (EU) 2015/1222 of 24 July 2015[1] establishing a guideline on capacity allocation and congestion management (CACM Regulation). CCR Hansa Transmission system operators (TSOs) are obliged to consult stakeholders on proposals for terms and conditions or methodologies required by the CACM Regulation.

The CCR Hansa covers several bidding-zone borders and is placed between two larger CCRs: CCR Nordic and CCR Core. This document has been written with the aim of ensuring that the methodology developed in the CCR Hansa is as efficient as possible from a market point of view and that it is easily implementable from an operational and security of supply point of view when coordinating with adjacent regions. Moreover, the methodology proposed is aimed at being sustainable for future changes in CCR configurations.

The CCR Hansa proposes a capacity calculation methodology based on a coordinated NTC methodology with a strong link to the adjacent CCRs that have chosen flow-based capacity calculation methodologies. By applying the flow-based capacity calculation methodologies of CCR Nordic and CCR Core in representing the AC meshed grids and using Advanced Hybrid Coupling for representing the CCR Hansa bidding-zone borders in the flow-based methodologies, the capacity calculation on the CCR Hansa borders is optimised to the fullest extent possible. This implicitly means that for CCR Hansa all AC grid limitations outside the CCR Hansa interconnectors are taken into account in the capacity calculations within CCR Nordic and CCR Core. The combination of the capacity calculation inputs from the adjacent CCR Nordic and CCR Core flow-based methodologies together with the capacity calculation results within CCR Hansa determine the cross-zonal capacity between the CCR Hansa bidding-zone borders, which shall be respected during the allocation process.

This document is structured as follows:

- Chapter 2 contains a description of the relevant legal references.
- Chapter 3 defines CCR Hansa and the borders that are subject to this proposal.
- Chapter 4 and 5 contain the explanation for the capacity calculation methodology for the day-ahead and intraday time frames presented in the legal proposal. The methodologies are described according to the requirements set in the CACM Regulation.
- Chapter 6 describes provisions that are common to both the day-ahead and intraday time frames.
- Chapter 7 contains an evaluation of the proposal against the objectives of the CACM Regulation.
- An explanation of the implementation phases can be found in Chapter 8.
- Public consultation responses are shown and commented on in Chapter 9.

[1] Commission Regulation (EU) 2015/1222 of 24 July 2015 establishing a guideline on capacity allocation and congestion management, OJ 25-7-2015, L 197/24.

Til arbejdsbrug/Restricted

2. Legal requirements

According to Article 20(2) of the CACM Regulation, each CCR is required to submit a common capacity calculation methodology for approval by the relevant national regulatory authorities (NRAs) for each capacity calculation time frame. This is to be done no later than 10 months after approval of the CCRs for the day-ahead and intraday time frame.

According to the CACM Regulation, the approach to be used in the capacity calculation methodology (CCM) for both the day-ahead and intraday time frame is the flow-based approach.[2] However, according to Article 20(7) of the CACM Regulation, CCR Hansa TSOs may jointly request the NRAs to apply the coordinated net transmission capacity approach (CNTC) in regions and on bidding-zone borders if the CCR Hansa TSOs are able to demonstrate that the application of the CCM using the flow-based approach would not yet be more efficient compared to the CNTC approach and assuming the same level of operational security in the concerned region.

In regard to the application of the flow-based approach, the preamble of the CACM Regulation, in point (7), states the following:
"*The flow-based approach should be used as a primary approach for day-ahead and intraday capacity calculation where cross-zonal capacity between bidding zones is highly interdependent. The flow-based approach should only be introduced after market participants have been consulted and given sufficient preparation time to allow for a smooth transition. The coordinated net transmission capacity approach should only be applied in regions where cross-zonal capacity is less interdependent and it can be shown that the flow-based approach would not bring added value*."

First, a number of relevant definitions from the CACM Regulation are stated below.

"'*coordinated net transmission capacity approach' means the capacity calculation method based on the principle of assessing and defining ex ante a maximum energy exchange between adjacent bidding zones*".[3]

"'*flow-based approach' means a capacity calculation method in which energy exchanges between bidding zones are limited by power transfer distribution factors and available margins on critical network elements*."[4]

"'*reliability margin' means the reduction of cross-zonal capacity to cover the uncertainties within capacity calculation*."[5]

"'*allocation constraints' means the constraints to be respected during capacity allocation to maintain the transmission system within operational security limits and have not been translated into cross-zonal capacity or that are needed to increase the efficiency of capacity allocation*;"[6]

"'*operational security limits' means the acceptable operating boundaries for secure grid operation such as thermal limits, voltage limits, short-circuit current limits, frequency and dynamic stability limits*;"[7]

"'*contingency' means the identified and possible or already occurred fault of an element, including not only the transmission system elements, but also significant grid users and distribution network elements if relevant for the transmission system operational security*;"[8]

[2] Article 20(1) of CACM Regulation.
[3] Article 2(8) of the CACM Regulation.
[4] Article 2(9) of the CACM Regulation.
[5] Article 2(14) of the CACM Regulation.
[6] Article 2(6) of the CACM Regulation.
[7] Article 2(7) of the CACM Regulation.
[8] Article 2(10) of the CACM Regulation.

Til arbejdsbrug/Restricted

"*'coordinated capacity calculator' means the entity or entities with the task of calculating transmission capacity, at regional level or above*;"[9]

"*'generation shift key' means a method of translating a net position change of a given bidding zone into estimated specific injection increases or decreases in the common grid model*;"[10]

"*'remedial action' means any measure applied by a TSO or several TSOs, manually or automatically, in order to maintain operational security."*[11]

Secondly, in Article 21 the CACM Regulation sets further requirements for the proposal for a CCM.

"1. *The proposal for a common capacity calculation methodology for a capacity calculation region determined in accordance with Article 20(2) shall include at least the following items for each capacity calculation time frame:*

a) methodologies for the calculation of the inputs to capacity calculation, which shall include the following parameters:
   - *I. a methodology for determining the reliability margin in accordance with Article 22;*
   - *II. the methodologies for determining operational security limits, contingencies relevant to capacity calculation and allocation constraints that may be applied in accordance with Article 23;*
   - *III. the methodology for determining the generation shift keys in accordance with Article 24;*
   - *IV. the methodology for determining remedial actions to be considered in capacity calculation in accordance with Article 25.*

b) detailed description of the capacity calculation approach which shall include the following:
   - *I. a mathematical description of the applied capacity calculation approach with different capacity calculation inputs;*
   - *II. rules for avoiding undue discrimination between internal and cross-zonal exchanges to ensure compliance with point 1.7 of Annex I to Regulation (EC) No 714/2009;*
   - *III. rules for taking into account, where appropriate, previously allocated cross-zonal capacity;*
   - *IV. rules on the adjustment of power flows on critical network elements or of cross-zonal capacity due to remedial actions in accordance with Article 25;*
   - *V. for the flow-based approach, a mathematical description of the calculation of power transfer distribution factors and of the calculation of available margins on critical network elements;*
   - *VI. for the coordinated net transmission capacity approach, the rules for calculating cross-zonal capacity, including the rules for efficiently sharing the power flow capabilities of critical network elements among different bidding-zone borders;*
   - *VII. where the power flows on critical network elements are influenced by cross-zonal power exchanges in different capacity calculation regions, the rules for sharing the power flow capabilities of critical network elements among different capacity calculation regions in order to accommodate these flows.*

c) a methodology for the validation of cross-zonal capacity in accordance with Article 26.

[9] Article 2(11) of the CACM Regulation.
[10] Article 2(12) of the CACM Regulation.
[11] Article 2(13) of the CACM Regulation.

Til arbejdsbrug/Restricted

2. For the intraday capacity calculation time frame, the capacity calculation methodology shall also state the frequency at which capacity will be reassessed in accordance with Article 14(4), giving reasons for the chosen frequency.

3. The capacity calculation methodology shall include a fallback procedure for the case where the initial capacity calculation does not lead to any results."

The methodologies to be included in the proposal are further described in Articles 22 to 26 of the CACM Regulation.

According to Article 21(4) of the CACM Regulation, all CCR Hansa TSOs shall, as far as possible, use harmonised capacity calculation inputs. Therefore, the common capacity calculation methodology for the CCR Hansa should include compatible tools and principles suitable to be processed by the coordinated capacity calculator (CCC) in order to calculate the cross-zonal capacity values.

As a general point, all methodologies and proposals developed under the CACM Regulation should align with the objectives of Article 3 of the CACM Regulation. More specifically, Article 9(9) of the CACM Regulation requires that:
"The proposal for terms and conditions or methodologies shall include a proposed timescale for their implementation and a description of their expected impact on the objectives of this Regulation."

Future obligations are expected rising from the expected Clean Energy Package, e.g. additional requirements to the intraday timeframe and additional reporting obligations. The capacity calculation methodology does not hinder adaption of such future development in EU regulation.

Til arbejdsbrug/Restricted

3. Definition of bidding-zone borders in CCR Hansa

This methodology relates to the bidding-zone borders of CCR Hansa. In line with Article 4 of ACER's decision[12] on the determination of capacity calculation regions, CCR Hansa currently consists of the following bidding-zone borders:

1) Denmark 1 - Germany/Luxembourg (DK1-DE/LU)
   Energinet and TenneT TSO GmbH;
   Via onshore AC-grid connection
   Additional information on the DK1-DE/LU border is given in section 3.1

2) Denmark 2 - Germany/Luxembourg (DK2-DE/LU)
   Energinet and 50Hertz Transmission GmbH;
   Via the Kontek HVDC interconnector and the Kriegers Flak Combined Grid Solution, a hybrid interconnector consisting of interconnected offshore wind farms in the DK2 and DE/LU bidding zone. Additional information on the Kriegers Flak CGS is given in section 3.2

3) Sweden 4 - Poland (SE4 – PL)
   Svenska Kraftnät and PSE S.A.
   Via the SwePol HVDC interconnector

4) Denmark 1 – the Netherlands (DK1-NL)
   Energinet and TenneT B.V.;
   Via the COBRAcable HVDC interconnector

5) Germany/Luxembourg – Sweden 4 (DE/LU-SE4)
   TenneT TSO GmbH, BalticCable and Svenska Kraftnät
   Via the BalticCable HVDC interconnector

6) Norway 2 – the Netherlands (NO2-NL)
   Statnett and TenneT TSO B.V.
   Via the NorNed interconnector

7) Germany/Luxembourg – Norway 2 (DE/LU-NO2)
   TenneT TSO GmbH and Statnett
   Via the NordLink HVDC interconnector

As is apparent from the list and table above, CCR Hansa largely consists of fully controllable HVDC interconnectors. There are two exceptions to this, the AC-grid border DK1-DE/LU and the Kriegers Flak CGS attributed to the DK2-DE/LU border, of which an additional description will be given in the next sections.

Additionally, in the upcoming years new interconnectors such as ~~Hansa Power Bridge /~~ Bornholm Energy Island are expected to be added in the CCR Hansa.

[12] ACER decision 06-2016 of 17 November 2016.

Til arbejdsbrug/Restricted

3.1 Description of the Denmark 1 – Germany/Luxembourg AC border

CCR Hansa consists of several DC-connected borders and one AC-connected radial border. To understand the capacity calculation methodology and the related methodologies for remedial actions it is important to know the current topology of the AC border which is shown in Figure 2. The border DK1-DE/LU consist of two 380/400kV lines fully parallel which are connected into the same substation "Kassø" on the Danish side and "Audorf (South)" at the German side. Additionally, a third interconnector, the West-Coast-Line (WCL), is currently under construction.

At present, there are two phase-shifting transformers placed in Denmark at the substations where the 380/400kV lines connect. The aim of these is to equalize the distribution of flows between the lines and therefore to ensure the lines are not overloaded in operation.

There is no synchronous connection from DK1 to DK2 or Scandinavia. DK1 is only connected with AC lines to the German grid. This means that currently all exchanges between DK1 and DE have to flow from Kassø to Audorf until the connection of the Danish grid to the WCL is realized. Only the grid between Kassø and Audorf is represented within the capacity calculation of CCR Hansa. Due to historic reasons, significant parts of Flensburg are supplied from Denmark and is part of the market in DK1.

Til arbejdsbrug/Restricted



Figure 1: Topological overview of the Denmark West (DK1) – Germany (DE/LU) AC connection within CCR Hansa. Each red line represents a 380/400kV interconnector, consisting of a double circuit across the onshore border between Denmark (DK1) and Germany (DE/LU). ~~*The West Coast line from Klixbül to Endrup is not commissioned yet.*~~

Since all three cross-border connections run in parallel, the DK1-DE/LU border is considered radial and no loop flows can occur.

3.2 Description of Kriegers Flak Combined Grid Solution

Since 2020, two separate connections are making up the DK2-DE/LU bidding-zone border. The existing KONTEK DC interconnector and the Kriegers Flak Combined Grid Solution (KF CGS).

KF CGS is a novel type of CCR Hansa interconnector, being a hybrid with interconnector and offshore wind farm (OWF) grid connection.

Due to the fact that the transmission grids in Eastern Denmark and Germany, respectively, belong to different synchronous areas and thus are operated non-synchronously, KF CGS, in case it being solely a CCR Hansa interconnector between Eastern Denmark and Germany with no OWFs connected to it, would have been set up as an ordinary DC line. For both technical and economic reasons, KF CGS is set up as an AC line, however with a back-to-back converter which is located at one of its ends and converts AC into DC and back into AC and thus enables the connection of the Nordic synchronous area with the one in continental European synchronous areas.

KF CGS is comprised of

- a back-to-back converter station at the German terminal of KF CGS.
- two German OWFs that feed into the German bidding zone through an AC radial grid connection.
- an AC cable connecting the grid connection of the German OWFs with the grid connection of the Danish OWFs.
- one Danish OWF that feeds into the DK2 bidding zone through an AC radial grid connection

Despite its technical setup, KF CGS behaves in operational terms like an ordinary DC link and therefore is to be treated as such.

Til arbejdsbrug/Restricted



Figure 2 Conceptual sketch of KF CGS that is constituted of parts from a Danish OWF (with two offshore substations), two German OWFs, a connecting cable between the OWFs, and a back-to-back converter station. Green colours indicate parts of KF CGS stemming from the Danish OWF, blue colours show parts stemming from the German OWFs, and red colours show parts stemming from the CCR Hansa interconnector.

As such, KF CGS is not directly comparable to a traditional interconnector, regardless of it being a DC or an AC connection, but is instead a hybrid. When the capacity for the DK2-DE/LU bidding-zone border is calculated, the hybrid nature of KF CGS means that special considerations have to be made in the capacity calculation methodology.

The hybrid nature of KF CGS has two concrete implications for the possibility of transmitting energy between the DK2 and DE/LU bidding zones.

1. The forecasted generation of the German OWF(s) [of the Danish OWF(s)] reduces the import capacity of the German bidding zone [of the Danish bidding zone] over KF CGS.
2. The forecasted generation of the German OWF(s) [of the Danish OWF(s)] can in some cases increase the export capacity of the German bidding zone [of the Danish bidding zone] over KF CGS.

Regarding point 1, the capacity that can be given to the market depends on the forecasted generation of the OWFs since the KF CGS CCR Hansa interconnector can only utilise the share in the transmission capacity on KF CGS which is not needed to transmit the electricity generation of the German and Danish OWFs to the respective national transmission grid.

OWF generation has prioritised access to the transmission capacity towards its home market which directly reduces the capacity available for the electricity markets. This is reflected in the mathematical description of the capacity calculation methodology as a forecast term related to already allocated capacity.

Regarding point 2, the fact that generation units are physically located on the CCR Hansa interconnector implies that wind generation can supplement the flow on the CCR Hansa interconnector. In the case where the sending end terminal constitutes a binding constraint (a bottleneck) for the capacity calculation, wind generation at the sending OWF can compensate for the transmission loss between the constraint and the OWF to allow a higher market capacity. However, as wind offshore farms connected to KF CGS are increasingly reacting to market prices, occurrences of self-curtailment are becoming more common. Real-time wind feed-in can therefore decrease to zero, whereas the KF CGS NTC calculation relies on wind forecasts, which are unable to capture the self-curtailing behavior. Thus, NTCs cannot rely on predicted wind feed-in for loss compensation anymore. Due to this uncertainty, the ~~a~~ KF CGS specific forecast term related to the loss factor was deleted ~~In~~ from the mathematical description of the capacity calculation methodology ~~this is introduced as a KF CGS specific forecast term related to the loss factor. This is especially relevant for the northbound market capacity~~.

Conceptually, KF CGS consists of three sections, as shown in Figure 4, with section 1 being the radial grid connection of the Danish OWF to DK2 (capacity of 600 MW), section 2 being the cable connection

Til arbejdsbrug/Restricted

between the Danish OWFs and the German OWFs (capacity of about 400 MW), and section 3 being the radial grid connection of the Germans OWFs to Germany (capacity of about 400 MW).



Figure 3 Conceptual illustration of transmission capacity of different sections of KF CGS

For the northbound capacity, transmission losses imply that section 3 is a bottleneck, such that the transmission capacity of about 400 MW can never be fully utilised with northbound flow.

Using the generation of the German OWFs located physically at the interface between section 2 and 3 partly, or if so, completely for covering the grid losses on section 3 moves the bottleneck from section 3 to section 2. This means that the market capacity can be increased by the equivalent of the full load grid losses of section 3.

For the southbound capacity, section 2 is the bottleneck from the outset, since the transmission capacity of section 1 is higher than that of section 2. Only in case of an outage on section 1 can this section constitute a bottleneck, in which case forecasted generation on the Danish OWFs can increase the market capacity.

The KF CGS was granted a 10-year exception with the EC decision no. 2020/7948 of 11 November 2020 on the derogation for KF CGS following Article 64 of Regulation (EU) 2019/943. The decision sets that the capacity basis to be used for calculating the minimum capacity shall be the residual capacity after deduction of the capacity necessary for transporting the forecasted electricity production by the wind farms connected to the Kriegers Flak Combined Grid Facility at the day ahead stage to the respective national onshore systems, rather than the total transmission capacity. The Hansa CCM is reflecting this decision in the solutions described for KF CGS throughout the Hansa CCM.

Til arbejdsbrug/Restricted

4. Capacity calculation methodology for the day-ahead time frame

This chapter describes the target capacity calculation methodology which will be applied for CCR Hansa bidding-zone borders in the day-ahead time frame.

4.1 Rules for calculating cross-zonal capacity

Article 2 in the CCM for CCR Hansa details the most important definitions and principles. Art. 2(1) a, c and d describe that NTCs are calculated by TSOs or CCCs, that sources for AACs are listed in Art. 11 and 15 and that the combination of both results in the ATCs provided to the market. It adds clarity to what constitutes the actualization of the CNTC approach (namely computing NTCs) in contrast to AACs, which is complementary information to provide the markets with available capacities, namely ATCs.

Article 3 in the CCM for CCR Hansa describes the rules for calculating cross-zonal capacity in CCR Hansa and makes several references to the relevant articles in the CACM Regulation.

The capacity calculation approach for CCR Hansa follows the coordinated net transmission capacity (CNTC) approach. As written in CACM Regulation Article 20(7), CCR Hansa TSOs may jointly request the competent regulatory authorities to apply the CNTC approach, if the CCR Hansa TSOs are able to demonstrate that the application of the capacity calculation methodology using the flow-based approach would not yet be more efficient compared to the CNTC approach assuming the same level of operational security in the concerned region.

Except for the KF CGS, the CCR Hansa TSOs will provide the CCC with the information listed in Article 3(3) of the CCM for each market time unit. For the KF CGS inputs are provided as listed in Article 3(4). Where relevant (as per Article 11), CCR Hansa TSOs will provide AAC values to the CCC.

This information is necessary for the CCC to calculate the cross-border capacity in both directions for the CCR Hansa bidding-zone borders.

The rules also specify that if the capacity calculation cannot be performed by the CCC, then the fallback proposals will apply.

The rules also state that the CCC shall submit the results of the capacity calculation to the CCR Hansa TSOs for validation and, in the end, make sure that the validated cross-zonal capacities and allocation constraints are provided to the relevant NEMOs before the day-ahead and intraday firmness deadline following CACM Regulation Articles 69 and 58.

4.2 Description of the capacity calculation methodology in CCR Hansa

The capacity calculation methodology proposed for the day-ahead time frame unifies 3 congestion-relevant parts. It takes advantage of the flow-based methodologies with the AHC approach developed in CCR Nordic and CCR Core in order to represent the limitations in the AC grids, while the actual CCR Hansa interconnector capacities are addressed individually within CCR Hansa.

Til arbejdsbrug/Restricted



Figure 4: Capacity calculation in CCR CORE, CCR Nordic, and CCR Hansa

Til arbejdsbrug/Restricted

Cross-border trade between bidding zones always affects at least three different parts of the grid:

1. The AC grid sensitive to the trade surrounding the CCR Hansa interconnector on the exporting side;
2. The CCR Hansa interconnector itself;
3. The AC grid sensitive to the trade surrounding the CCR Hansa interconnector on the importing side.

This holds true for all cross-border trade, irrespective of the type of CCR Hansa interconnector (AC or DC) or the applied capacity calculation methodology (NTC or flow-based).
Years of experience with capacity calculation have shown that a congestion resulting from a cross-border trade can occur in each of these three parts of the grid. In order to maintain system security, it is therefore necessary to take all three parts into account in the capacity calculation.

Since CCR Hansa has the unique feature that all bidding zones are currently connected by means of radial lines, the assessment of cross-border capacity can be split into three separate parts. This allows the CCR Hansa TSOs to look at the impact of cross-border trade independently on each part of the grid.

The methodology is thus based on three parts, as depicted in Table 1.

1. The actual CCR Hansa interconnector capacity within the CCR Hansa;
2. The limitations on the CCR Hansa interconnectors from the AC grid handled by AHC in CCR Core;
3. The limitations on the CCR Hansa interconnectors from the AC grid handled by AHC in CCR Nordic.

These three contributions together deliver the limits on flow on the CCR Hansa interconnectors and can be represented as in Table 1. The flexibility the methodology allows for is to contain both flow-based restrictions as well as CNTC restrictions at the same time.

	Core AHC	Actual Interconnector Capacity	Nordic AHC
TSO1→TSO2		1400MW	
TSO2→TSO3		600MW	
TSO1→TSO4		1000MW	
	Part of Core CC	Part of Hansa CC	Part of Nordic CC

Table 1: An example of the capacity calculation in CCR Core, CCR Nordic and CCR Hansa

In a CNTC methodology, the following terminologies are used. The NTC is the maximum total exchange program between two adjacent bidding zones compatible with security standards, and taking into account the technical uncertainties on future network conditions and a loss factor if implicit grid loss handling is applied.

The capacity calculation is done for each day-ahead and intraday market time unit

Til arbejdsbrug/Restricted

4.2.1. Mathematical description of the applied approach

The calculation of the actual CCR Hansa interconnector capacity, as shown in Figure 6, is based mainly on the physical properties of the cross-border lines and stations on each end. As CCR Hansa contains DC borders, radial AC border and KF CGS, being a hybrid CCR Hansa interconnector and offshore wind farm (OWF) grid connection between Germany and Denmark, these have to be addressed separately in an ex-ante process. The following aspects should be taken into account when calculating the actual CCR Hansa interconnector capacity for the AC and the DC borders as well as KF CGS.



Figure 5: The actual CCR Hansa interconnector capacity which is the responsibility of CCR Hansa to determine

1. CCR Hansa TSOs calculate capacity on a bidding-zone border connected with DC lines or in case of KF CGS on a line per line basis, in the following named DC line i. On a bidding-zone border with AC connections, the transfer capacity on the whole bidding-zone border is computed, as it is not possible to control the division of flow between AC lines, in the case there are parallel lines across the border. The capacity shall be calculated for both directions, A➔B and B➔A.

   The $NTC_{i,DC,A\rightarrow B}$ on a DC line i in the direction A➔B is calculated as follows:

$$NTC_{i,DC\ A\rightarrow B} = \alpha_i \cdot P_{i,maxthermal} * (1 - \beta_{i,Loss,A\rightarrow B})$$

   A := Bidding zone A.

   B := Bidding zone B.

Til arbejdsbrug/Restricted

α_i := Availability factor of equipment defined through scheduled and unscheduled outages, α_i, being a real number in between and including 0 and 1.

$P_{i,max\ thermal}$:= Thermal capacity for a DC line i.

$\beta_{i.Loss,A\rightarrow B}$:= Loss factor in case of explicit grid loss handling on a DC line i in direction A➔B, can be a different value depending on α_i. In case of implicit loss handling, the loss factor is set to zero but taken into account as an allocation constraint in accordance with Article 8.

2. The following mathematical description applies for the calculation of NTC on the AC lines between bidding zones. The capacity shall be calculated for both directions, A➔B and B➔A.

The $NTC_{AC,A\rightarrow B}$ on a bidding-zone border that is connected by AC lines in the direction A➔B is calculated as follows:

$$NTC_{AC,\ A\rightarrow B} = TTC_{A\rightarrow B} - TRM_{A\rightarrow B}$$

A := Bidding zone A.

B := Bidding zone B.

Til arbejdsbrug/Restricted

$\mathrm{TTC}_{\mathrm{A}\to\mathrm{B}}$:= Total Transfer Capacity of a bidding-zone border in direction A➔B.
The TTC is determined according to the following steps:

1. Performing load-flow calculation using the CGM and the GSKs according to Article 9
2. When assessing the loading of the individual circuits of the CCR Hansa Interconnector, and to take N-1 security criterion into account, the processes of points 3 and 4 are repeated with the outage of each of the individual circuits on the CCR Hansa Interconnector where the minimum TTC for each CCR Hansa Interconnector and in each direction is set as TTC in the given direction.
3. Using the GSK to increase the net position of bidding zone A while decreasing the net position of bidding zone B at equal amounts until a circuit or multiple circuits of the CCR Hansa Interconnector reach their permanent admissible thermal loading. The TTC is then equal to the maximum exchange between the bidding zones.
4. The process of point 3 is repeated in the opposite direction to determine the TTC in the direction B to A.

$\mathrm{TRM}_{\mathrm{A}\to\mathrm{B}}$:= Transmission Reliability Margin for a bidding-zone border in direction A➔B, in accordance with Article 6.

3. Article 4(3) and 12(3) give a mathematical description as an approximation of the autonomous calculation of NTCs by the MIO on the KF CGS, a hybrid interconnector and OWFs grid connection between DK2-DE/LU. It is important to note that the MIO may, in some situations, calculate a higher capacity than what the approximation formula will result in, since the formula is a linearized approximation of the non-linear NTC calculations of the MIO. The objective function of the MIO's capacity calculation is the maximization of NTCs on KF CGS, considering OWFs infeed, grid losses, active and reactive power as well as physical limits of the assets.

   Article 4(3) and 12(3) give the *NTC* definitions for the KF CGS. The formula contains $\mathrm{AAC}^{\mathrm{Wind}}$ elements, which are, however, not market allocations but wind allocations. When deducting these, the resulting NTC is provided to the market. That a difference in AACs exists, is included in Art. 2(1)d.

   To complement Art. 4(3) and 12(3), Recital 18 states that the MIO is a separate system operator, autonomously calculation the cross-zonal capacities. Further, Art. 3(4) details that the information provided to the CCC differ for the KF CGS. Due to the hybrid nature of the interconnector, its NTC calculation cannot be divided up into linearized parts as can be done for other borders.

4.2.2 Capacity limitations originating from the AC grid handled by AHC in CCR Nordic

The capacity of a DC line (being a fully controllable active power flow) is a NTC by nature. CCR Nordic has decided to handle the power flows of DC lines with the AHC approach, see Annex 2. This means that the flows on the DC lines are competing for the scarce capacity on the AC grid, like the exchanges from any of the other Nordic bidding zones (SE1, SE2, NO1, FI, and so on).

Til arbejdsbrug/Restricted

The converter stations of the CCR Hansa DC interconnectors are modelled as 'virtual' bidding zones in the flow-based system (however a bidding zone, without production and consumption), having their own PTDF factors reflecting how exchanges on the DC lines are impacting the AC grid elements. Radial AC connections can be handled in the same way. This is illustrated in Figure 7.

CCR Nordic provides a flow-based representation of the AC grid in the Nordic area, which is imposing AC grid limitations on the commercial exchanges over the Hansa lines as well.



Figure 6: Advanced hybrid coupling in CCR Nordic

4.2.3. Capacity limitations originating from the AC grid handled by AHC in CCR Core

The capacity of a DC line (being a fully controllable active power flow) is a NTC by nature.
CCR Core decided to handle the power flows of DC lines with the AHC[13] approach as target model. This means that the flows on the DC lines are competing for the scarce capacity on the AC grid, like the exchanges from any of the other Core bidding zones (NL, DE, PL, FR, and so on). The converter stations of the CCR Hansa DC interconnectors are modelled as 'virtual' bidding zones in the flow-based system (a bidding zone without production and consumption), having their own PTDF factors reflecting how exchanges on the DC lines are impacting the AC grid elements. Radial AC connections can be handled in the same way. This is illustrated in Figure 8.

[13] See Annex 2 for explanation of AHC

Til arbejdsbrug/Restricted

CCR Core provides a flow-based representation of the AC grid in the Core area, which is imposing AC grid limitations on the commercial exchanges over the Hansa lines as well.



Figure 7: Advanced hybrid coupling in CCR Core and Nordics

4.2.4. Further requirements from Article 21(1)(b) of the CACM Regulation

In the following section, the requirements set out in Article 21(1)(b) of the CACM Regulation for a detailed description of the capacity calculation approach are listed, and it is explained how the CCM of CCR Hansa fulfils these requirements.

***(ii) rules for avoiding undue discrimination between internal and cross-zonal exchanges to ensure compliance with point 1.7 of Annex I to Regulation (EC) No 714/2009*;**

Article 5 in the CCM for CCR Hansa states the methodology for selecting CNEs and rules for avoiding undue discrimination between internal and cross-zonal exchanges. The CCR Hansa TSOs are in general responsible for identifying the CNEs that are relevant for capacity calculation. As the CCR Hansa CCM is based on a principle of applying CNTC on the cross-zonal grid elements while handling any relevant grid constraints in the meshed AC grid with flow-based, for which it is better than NTC, the CCR Hansa CCM will only include the CCR Hansa Interconnectors. The TSOs will, within the flow-based methodologies, include the AC grid CNEs that are relevant to monitor to ensure security of supply. This means that CCR Hansa relies on CCR Nordic and CCR Core to include these CNEs in the flow-based methodologies and the rules to avoid undue discrimination between internal and cross-zonal exchanges developed there. This principle has been agreed with both CCR Nordic and Core, and the flow-based calculations in these two regions will be including the relevant AC limitations when AHC in implemented in 2024 (Nordic) and 2025 (Core).

As the internal flows within the bidding zones are to be handled via flow-based allocation in the adjacent CCRs, along with the representation of the CCR Hansa interconnectors with AHC, the allocation of capacity to the interconnectors will be based on a mathematical optimisation in the allocation process. Thus, there is no possibility to discriminate one type of flow to another within CCR Hansa. Also taking into account that the methodology only includes the CCR Hansa Interconnectors as previously mentioned, there is no possibility to distinguish between internal and cross-zonal flows within the CCR Hansa CCM, which means there can be no discrimination.

(iii) rules for taking into account, where appropriate, previously allocated cross-zonal capacity;

Til arbejdsbrug/Restricted

The previously allocated cross-zonal capacity can be subtracted from the actual CCR Hansa interconnector capacity which is described in section 4.7.

(iv) rules on the adjustment of power flows on critical network elements or of cross-zonal capacity due to remedial actions in accordance with Article 25;
In case it would be necessary to adjust the power flow on the CNEs taken into account in the CCM, it will be done by adjusting the cross-zonal capacity of the bidding-zone border where the remedial action has effect in either direction, as written in Article 10(7) in the CCM for CCR Hansa.

In case the remedial action is situated in the adjacent AC grid, it will be done by adjusting the size of the flow-based domain. The determination of where this adjusted flow-based domain is utilised will be left to the market allocation algorithm optimisation.

(v) for the flow-based approach, a mathematical description of the calculation of power transfer distribution factors and of the calculation of available margins on critical network elements;
Not applicable, as this will be handled in the flow-based methodologies of CCR Nordic and CCR Core.

(vi) for the coordinated net transmission capacity approach, the rules for calculating cross-zonal capacity, including the rules for efficiently sharing the power flow capabilities of critical network elements among different bidding-zone borders;
As the methodology chosen utilises flow-based domains from the two adjacent CCRs to ensure optimal market efficiency when handling constraints from the AC grids, there is no ex-ante split of capacity on CNEs. The methodology only takes cross-border elements and the radial lines associated with these into account, thus there are no CNEs of which the power-flow capabilities have to be shared. This is specified in Article 17 of the CCM for CCR Hansa.

(vii) where the power flows on critical network elements are influenced by cross-zonal power exchanges in different capacity calculation regions, the rules for sharing the power flow capabilities of critical network elements among different capacity calculation regions in order to accommodate these flows.
The use of AHC in CCR Core and CCR Nordic ensures that an economic optimisation determines where capacities are allocated between borders and different capacity calculation regions. The methodology only takes cross-border elements and the radial lines associated with these into account, thus there are no CNEs of which the power-flow capabilities have to be shared. This is specified in Article 17 of the CCM for CCR Hansa.

4.3 Methodology for determining the Transmission Reliability Margin

The methodology to determine the reliability margin, for cross-zonal capacity in CCR Hansa, includes the principles for calculating the probability distribution of the deviations between the expected power flows at the time of the capacity calculation, and realised power flows in real time, and subsequently specifies the uncertainties to be taken into account in the capacity calculation, being the TRM mentioned in section 4.2.1. The following description sets out common harmonised principles for deriving the reliability margin from the probability distribution, as required in Article 22(3) of the CACM Regulation.

Due to the controllability of the power flow over DC interconnections, the determination of a reliability margin does not need to be applied on bidding-zone borders only connected by DC interconnections. Also for the remaining Hansa interconnectors, such as the hybrid interconnector KF CGS (DK2-DE/LU) as well as the AC border DK1-DE/LU currently no reliability margin is applied.

In general, the cross-border capacity derived for the AC border in CCR Hansa is expressed as an NTC value. During the capacity calculation, the CCR Hansa TSOs apply the TRM in order to hedge against

Til arbejdsbrug/Restricted

risks inherent in the calculation. The methodology for the TRM is determined by the CCR Hansa TSOs and reflects the risks that the CCR Hansa TSOs are facing. As demanded by Article 22(2) of the CACM Regulation, the presented methodology in particular takes into account:

"(a) Unintended deviations of physical electricity flows within a market time unit caused by the adjustment of electricity flows within and between control areas, to maintain a constant frequency;
(b) Uncertainties which could affect capacity calculation and which could occur between the capacity calculation time frame and real time, for the market time unit being considered."

The TRM calculation consists of the following high-level steps:

1. Identification of sources of uncertainty for each TTC calculation process;
2. Derivation of independent time series for each uncertainty and determination of probability distributions (PD) of each time series;
3. Convolution of individual PDs and derivation of the TRM value from the convoluted PD.

The method is illustrated in the figure below.



Figure 8: Illustration of the concept used to calculate the TRM

Below, the individual steps are described in more detail.

Step 1: Identification of sources of uncertainty
In the first step, the corresponding uncertainties are identified. In general, the TTC calculation is based on the CGM, which includes assumptions and forecasts for the generation and load pattern as well as for the grid topology. This is the starting point to identify specific sources of uncertainty. For the AC border in CCR Hansa, typical sources of uncertainty at the capacity calculation stage are:

1. Inaccuracy of forecasts for wind, load and solar infeed, which impact the load and generation pattern in the network model;
2. Assumptions of cross-border exchange between third countries which are not part of the TTC profile;
3. Exchange of frequency containment reserve (FCR).

Til arbejdsbrug/Restricted

Step 2: Determination of appropriate probability distributions
The second step of the TRM calculation is the determination of appropriate time series that measure or estimate the effect of each uncertainty on the TTC calculation. Depending on the nature of the uncertainty, the determination of such time series can differ. In general, generic time series from an already existing data base can be used as a starting point. The time series cover an appropriate timespan from the past in order to get a significant and representative amount of data. After performing quality checks, the impact of the uncertainty on the TTC calculation is determined.

Step 3: Convolution and TRM calculation
At the beginning of this step, the individual PDs are convoluted to get the overall PD for an event. The convolution of the PDs of the relevant uncertainties merges the individual independent factors into one common PD for one TRM. Before the convolution is made, each PD is normalised. The convoluted PD is the basis for the determination of initial TRM values. From the convoluted PD, a certain percentile is taken.

4.4 Methodologies for determining operational security limits, contingencies relevant to capacity calculation and allocation constraints

In accordance with Article 23(1) of the CACM Regulation, CCR Hansa TSOs shall respect the operational security limits used in operational security analysis carried out in line with Article 72 of the SO Regulation. The operational security limits used in the common capacity calculation are the same as those used in operational security analysis, therefore any additional descriptions pursuant to Article 23(2) of the CACM Regulation are not needed.

In particular, the following operational security limits and contingencies shall be used in the operational security analysis:

- steady-state thermal limits
- voltage stability
- frequency and dynamic transient stability
- short-circuit ratio (SCR)
- security of supply (interaction with distribution network)
- identified and possible or already-occurred fault of the transmission system element
- identified and possible or already-occurred fault of the significant grid users if relevant for the transmission system operational security
- identified and possible or already-occurred fault of the distribution network element if relevant for the transmission system operational security

Steady-state thermal limits of CCR Hansa interconnectors are considered in the TTC calculation process described in the sections 4.2 and 5.1. Operational security limits and contingencies of adjacent AC grid elements, reflecting interactions between CCR Hansa interconnectors and the AC grids, are generally handled by the flow-based capacity calculation methodologies in CCR Core and CCR Nordic. However, with regards to the DE/LU-SE4 border (Baltic Cable) a temporary exception shall apply as operational security limits of the local DSO grid on the German side significantly impact the (operational) characteristics of the interconnector and therefore co-determine the available cross-border capacity at the respective bidding zone border. As this exceptional case currently is not considered in the CCR Core capacity calculation, a temporary exception was added to this methodology. A detailed explanation on this can be found in Annex 3 of this document.

Operational security limits which cannot be evaluated in the frame of flow-based calculations of adjacent CCRs (e.g. voltage stability, dynamic stability, short-circuit limits, etc.) are assessed by individual CCR Hansa TSOs who perform the simulations in their offline tools using a CGM. The results are translated into cross-zonal capacity constraints, e.g. as constraints of particular virtual bidding zones

Til arbejdsbrug/Restricted

representing CCR Hansa interconnectors, that are respected during capacity allocation.

In accordance with Article 23(3)(a) or (b) of the CACM Regulation, CCR Hansa TSOs, besides active power-flow limits on CCR Hansa interconnectors, may apply allocation constraints which means constraints to be respected during capacity allocation to maintain the transmission system within operational security limits or constraints that are needed to increase the efficiency of capacity allocation and that cannot not be translated into cross-zonal capacity limitations, including:

- The combined import or export from one bidding zone to other adjacent bidding zones shall be limited in order to ensure adequate level of generation reserves required for secure system operation
- Maximum flow change on DC-lines between MTUs (ramping restrictions)
- Implicit loss factors on DC-lines
- Minimum flow on DC lines
- Limitations of amount of polarity reversals (zero-crossings) on DC lines for a given period of time
- Limitations of maximum flow on DC lines dependent on cable temperature and cable pressure.

The following subsections provide additional information about each allocation constraint.

Import or export limits

Allocation constraints may include balancing constraints (import/export limits) that are determined for those systems where a central dispatch market model is applied, i.e. where the CCR Hansa TSO acts as the balance responsible party for the whole control area and procures reserves in an integrated scheduling process run after the day ahead market closure. In order to execute this task, the CCR Hansa TSO in central dispatch systems needs to ensure the availability of sufficient upward or downward regulation reserves for maintaining secure power system operation. This takes form of allocation constraints that vary depending on the foreseen balancing situation. Application of allocation constraints to reflect balancing constraints in capacity allocation process ensures efficiency in distribution of balancing constraints on interconnections and maximise social welfare. For details see Annex 1.

Import or export limits are constraints that are needed to maintain the transmission system within operational security limits and that cannot be transformed efficiently into maximum flows on critical network elements (fall under CACM Art. 23(3)a). They are already part of the SDAC and SIDC solutions, in line with the Hansa DA/ID CCM Art. 8.

Ramping restrictions

A ramping restriction is an instrument of system operation to maintain system security (frequency management purposes) or to ensure that the maximum flow change on HVDC interconnections between market time units is kept within the technical limits of HVDC interconnections. This sets the maximum change in DC flows between MTUs (max. MW/MTU per CCR Hansa interconnector). As opposed to the balancing timeframe, ramping restrictions within MTUs are not applicable for the day ahead or intraday timeframes.

Ramping restriction allocation constraints are already part of the SDAC and SIDC solutions, in line with the Hansa Capacity Calculation Methodology articles 8 and 12. They are based on an approved method according to SOGL 137 for HVDC bidding zone borders between synchronous areas. Ramping restrictions are therefore included in the Hansa Capacity Calculation and sent to the NEMOs SDAC and SIDC solutions.

Implicit loss factors

Implicit loss factor on DC lines during capacity allocation ensures that the DC line will not flow unless the welfare gain of flowing exceeds the costs of the corresponding losses.

The implicit losses functionality is already part of the SDAC solution (Euphemia), in line with the Hansa

Til arbejdsbrug/Restricted

Capacity Calculation Methodology article 8. The loss factor is included in the Hansa Day Ahead Capacity Calculation and is being sent to the relevant NEMOs.

Minimum flow on DC lines

Some interconnectors are not able to operate with a power flow close to zero. This means there is a technical dead band on the interconnector – e.g. for NorNed this dead band is 30MW. If the market result is within this dead band today the TSOs will force the flow to be outside the dead band. This creates an imbalance on both sides of the interconnector as the power flow is no longer equal to the market flow.

These imbalances are not very large and are not seen as a big problem today. In the future we expect much more volatility on the interconnectors, and thus a market result within the dead band must be expected much more often than today. Considering a minimum flow on each DC line during capacity allocation would ensure that the DC line will not be operated outside its technical capabilities. This would mean the actual flow on the interconnector could be set equal to the market flow and we would remove the problem of imbalances caused by dead bands.

This allocation constraint affects both the operational security and the socio-economical welfare. On the one hand the minimum flow is determined by the cable manufacturer and thus directly relates to the wear and tear of the technical equipment, whereas on the other hand the operation of the cables within the dead band will lead to energy imbalances that subsequently will need to be settled by balancing energy. Consequently, the resulting imbalance settlement price (which is not predictable) is likely to exceed by far the gain of the trade and thus diminishing overall socio-economical welfare.

Polarity reversals

Older HVDC systems were built for the market conditions at the time with quite stable operational patterns. In systems with line commutated converters, polarity reversals (changing the polarity of the voltage) are needed to change the flow direction of power but cause increased electrical stress in the cable insulation, which can in the long run reduce the life expectancy of the cable.

When changing the polarity of the voltage, you increase the risk of the insulation material gradually breaking down causing potential partial discharge (PD) due to temporary (up to approx. 1 hour) local high electric fields. Power reversals occur going from a high power in one direction to a power in the other direction and are made by first decreasing power, then shifting polarity and finally increasing power again. The temporary power reduction that is needed creates cooling and reduced pressure in the cable that gives an even greater risk of partial discharge.

The sensitivity to polarity reversals differs by cable and technology type. For example, one of the cable suppliers of mass-impregnated HVDC cables recommends keeping the number of polarity reversals below 1000 per year (the exact value depends on the technical characteristics of each cable), and this is also in line with the operating experience from many of the mass-impregnated cables systems in service today. The number 1000 is a very rough estimate and how "harmful" a specific polarity reversal is, is significantly more complex and depends on temperatures and voltage as well as their variation.

Several ongoing developments and trends in European electricity markets, such as increased price volatility, and the introduction of 15-minute MTUs and flow-based with AHC, cause, or are foreseen to cause, increased polarity reversals. It may therefore be necessary to introduce allocation constraints to avoid excessive wear and tear. Polarity reversals as an allocation constraint align with CACM Art. 23.3(a) and when implemented would have to be justified by the technical specifications or physical condition of the HVDC interconnection.

The CCR Hansa CCM does not specify exactly how an allocation constraint for polarity reversals shall be implemented. The inclusion of this allocation constraint would be a novel feature for the day-ahead and intraday markets, and the exact specifications need to take into account practical implications for

Til arbejdsbrug/Restricted

the day-ahead and intraday market algorithms, as well as weighing the benefits of maintaining the life expectancy of the cables against the socioeconomic costs of constraining market allocations. One important aspect of this will be to express the polarity reversal limitation at a time-granularity suitable for day-ahead and intraday timeframes. For example, X amount of polarity reversals per hours or day. Alternatively, each polarity reversal could be penalized [EUR per reversal] in the objective function. When the welfare gain due to the reversal is greater than the penalty, it will be actualized.

The following mathematical formulation provides an example of how the penalisation in terms of EUR per reversals could be implemented. For avoidance of doubt, the description is provided as an example and does not necessarily represent CCR Hansa's suggestion on how the AC should be calculated.

Let $EX_{A\to B,t}$ be the real (zero-positive) optimization variable representing exchange over the HVDC cable in MTU t and direction $A \to B$.

Let $EX_{B\to A,t-1}$ be the real (zero-positive) optimization variable representing exchange over the HVDC cable in the previous MTU $(t-1)$ and in the opposite direction $B \to A$.

Let ϵ be a numerical constant representing small tolerance value that can be configured (example: $\epsilon = 1\ MW$)

Let M be a numerical constant representing very high value which exchange HVDC polarity reversal in MTU t and direction $A \to B$

Let $b_{A\to B,t}$ be a binary optimization variable used to denote positive flow in MTU t and in the direction $A \to B$

Let $b_{B\to A,t-1}$ be a binary optimization variable used to denote positive flow in MTU $(t-1)$ and in the direction $B \to A$

Let $bpr_{A\to B,t}$ be a binary optimization variable which denotes HVDC polarity reversal in MTU t and the direction $A \to B$

Constraints to model polarity reversal in MTU t and the direction $A \to B$:

$$EX_{A\to B,t} \geq b_{A\to B,t} \cdot \epsilon$$
$$EX_{B\to A,t-1} \geq b_{B\to A,t-1} \cdot \epsilon$$
$$EX_{A\to B,t} \leq b_{A\to B,t} \cdot M$$
$$EX_{B\to A,t-1} \leq b_{B\to A,t-1} \cdot M$$

$$bpr_{A\to B,t} \geq b_{A\to B,t} + b_{B\to A,t-1} - 1$$
$$bpr_{A\to B,t} \leq b_{A\to B,t}$$
$$bpr_{A\to B,t} \leq b_{B\to A,t-1}$$

Let P_{A-B} be a numerical constant representing penalty cost (e.g. cable wear and tear) due to polarity reversal in MTU t on the HVDC cable $A \leftrightarrow B$

Penalty term added to the objective function $\boldsymbol{OF}$, in the case of polarity reversal ($bpr_{A\to B,t} = 1$):

$$\boldsymbol{OF} + bpr_{A\to B,t} \cdot P_{A-B}$$

Maximum flow

The maximum flow might be limited on some DC lines where cable technologies are sensitive to

Til arbejdsbrug/Restricted

changing cable temperature and pressure. The control systems of these DC lines can impose real-time restrictions to the operating voltage, which is set at a reduced value compared to the nominal voltage.

This reduced voltage mode is triggered when cable temperature and pressure thresholds are exceeded, e.g., in case of polarity reversal or ramp-up of the DC line and is only released/reset to nominal voltage when the control system deems it safe to do so. This is an in-built feature of the control system responsible for the DC line, to ensure the integrity of the cable is preserved and the effect of rapidly changing temperature and/or pressure does not negatively impact the cable's service life. The impact of a reduced voltage is a reduced maximum power flow for a period of time. Whether (or when) reduced voltage mode is triggered depends on the market outcome, and it is therefore not possible to ex-ante determine for which MTUs cross-zonal capacity needs to be reduced. Therefore, in order to ensure that the flow on the DC line can follow the market outcome, it may be necessary to reflect this limitation using an allocation constraint. Maximum flow constraints align with CACM Art. 23.3(a) and when implemented would have to be justified against this technical requirement, as it is essential for maintaining operational security by preventing excessive stress on HVDC cables, is based on dynamic, real-time factors that cannot be represented as a static maximum flow, and integrates into market coupling through a predictable and computationally feasible logic, which however cannot be represented by a simple maximum flow value of a single MTU.

General considerations regarding allocation constraints

Functionality for several of the allocation constraints described above are not yet implemented in the DA and/or ID timeframes, and it is currently not known how or when such functionality will be implemented, as the implementation on ACs are being performed outside of CCR Hansa's governance. These allocation constraints are nevertheless included in the CCR Hansa CCM such that they can be applied when the functionality becomes available.

The allocation constraints are included during the capacity allocation process and one allocation constraint can influence the interconnections belonging to the different CCRs.

The application of allocation constraints on one or more Hansa bidding zone borders (BZBs) will in most cases have an impact on the whole of CCR Hansa.

In view of such likely impacts, and principles of transparency and reliability of information, ref. to. e.g. Article 3(f) of the CACM Regulation, Hansa TSOs, planning on allocation constraints, are to inform market participants, other Hansa TSOs (not planning the allocation constraints), and all Hansa NRAs, on the plans for application of allocation constraints on Hansa BZBs according to Article 8(6).
If the relevant Hansa TSOs fail to follow this information procedure within the set timeline, the application of the allocation constraints in question may be deemed non-valid.
"Detailed descriptions and justifications" to accompany the information on allocation constraints refers to the substantial requirements for the relevant allocation constraint(s), referred to in Article 8(2) to (7), ref. to Article 8(1)(a) to (f), in the DA&ID CCM, and in Article 23(3)(a) or (b) of the CACM Regulation. Thus, the criteria, "economic surplus for single day-ahead or intraday coupling", within Article 23(3)(b) of the CACM Regulation, also refers to the definition thereof, in Article 2(46) of the CACM Regulation.

Based on the proposed rights for Hansa TSOs to introduce allocation constraints pursuant to Article 8(1) letters d) to f) there will first be a proposal submitted by the relevant TSOs to the Market Coupling Steering Committee. These proposals shall be submitted with a justification for the introduction of the constraint which can support the further weighing of trade-offs within the Market Coupling governance bodies. Such an analysis shall then be performed jointly between TSOs and NEMOs and be done on a case-by-case

Til arbejdsbrug/Restricted

basis, as the technical underlying and interconnector situations differ between Hansa TSOs. During such joint analysis, TSOs and NEMOs may take into account potential opportunity costs for the introduction of these constraints like counter-trading possibilities as well as additional implementation burden. Additionally, test calculations may be performed which would allow measuring the actual resulting complexities for finding solutions and market impacts, as well as identifying alternative countermeasures in the operation of the algorithm.

4.5 Methodology for determining the generation shift keys

The generation shift keys (GSKs) used to calculate the TTC values in CCR Hansa represent the best forecast of the relation of a change in the net position of a bidding zone to a specific change of generation or load in the common grid model. Due to the nature of the CCR Hansa interconnectors, the GSKs are applied to calculate the TTC values of the bidding-zone borders connected by CCR Hansa AC interconnectors.

On the radial AC connection between DK1 and DE, the GSKs of DK1 and DE, defined in the CCR Nordic and CCR Core respectively, are applied to represent the distribution of the power flow between the different cross-border lines. Each TSO is responsible for providing the updated corresponding GSK nodes and shifting methodology from corresponding adjacent CCR and any other relevant data to the CCC for the computation of regional capacity for the CCR once the role of capacity calculation is fully taken over by the CCC.

Any interaction between the CCR Hansa interconnectors and the adjacent AC grids, as described in 4.2, is modelled in the corresponding flow-based methodologies of CCR Core and CCR Nordic and is therefore not a part of this methodology.

4.6 Methodology for determining remedial actions to be considered in capacity calculation

When considering the use of remedial actions in capacity calculation, it is important to first and foremost understand the objective. The overall objective is to increase the economic efficiency of the European allocation process, thus, to give the market coupling algorithm as little constraint as possible while still ensuring system security.

Remedial actions are normally split into two categories, costly remedial actions such as countertrading and redispatching and non-costly remedial actions which include topological changes, modifying duration of planned outages, voltage control and manage reactive power or use of phase shifters. The CCM requires CCR Hansa TSOs to include non-costly remedial action, while costly remedial actions are not required specifically to be used for capacity calculation.

In CCR Hansa, only the cross-border lines are represented in capacity calculation, and capacity is given to the market in accordance with the mathematical description of sections 4.2.1 and 5.1.1.

In the CCM of CCR Nordic, the inclusion of CNEs in the flow-based capacity calculation is to be justified based on operational security (subject to a significancy threshold) and economic efficiency. If a CNE is not included in the flow-based domain, any congestion of this CNE will have to be handled by use of remedial actions when a security analysis shows that it is needed.

In the CCM of CCR Core, a different approach is taken. On all CNECs included in the flow-based domain, a certain level of capacity is reserved for cross-border exchanges. After capacity allocation, a security analysis will show if the use of remedial action is needed to handle congestions in the grid.

In CCR Hansa there are no bidding zone internal CNEs included in the capacity calculation.

Til arbejdsbrug/Restricted

Subsequently there are very limited possibilities to use remedial actions. Since the connection is radial, there cannot be a loop flow between the bidding zones DK1 and DE/LU. This leaves very little necessity to influence capacity on the radial AC connection and no necessity on the DC connections.

It is important to highlight that the CCR Hansa CCM aims at giving a maximum amount of capacity on the bidding-zone borders to the market. And given the scope of CCR Hansa CCM, there are only few possible limitations to the capacity calculated. When full capacity is given based on the conditions, then remedial actions will not be able to increase it, provided that capacity given to the market has to be kept within the physical possibilities.

The DK1-DE/LU border is consisting of a 380/400kV interconnector, consisting of a double circuit across the onshore border between Denmark (DK1) and Germany (DE/LU). Therefore, there will be no remedial actions available within CCR Hansa which can be utilised to influence the flow distribution on the cross-border lines. The impact of remedial actions that is available is considered in the determination of the TTC value as shown in section 4.2.1. Furthermore, it is important to note that the remedial actions found in bidding zones, in general, will be taken into account in the flow-based methodologies of CCR Nordic and CCR Core to enlarge the overall flow-based domains in the favoured market direction. This will, in turn, also positively impact the cross-border capabilities of CCR Hansa if it increases the European economic welfare.

In terms of using costly remedial actions, redispatching within a bidding zone will have no effect on the radial AC connection or the two DC connections in CCR Hansa. Redispatching of generation can generally not influence the capacity on a DC line. The location of the generation assets and thereby the use of redispatching is however of importance when addressing internal constraints within bidding zones. In these cases, the redispatching should be utilised by CCR Nordic or CCR Core in enlarging the flow-based domains, as described above, prior to capacity allocation and to handle violation of operational security limits after the operational security analysis.

As countertrading generally brings market capacities beyond the physical limitations when used in capacity calculation, for CCR Hansa it is currently exclusively applied to safeguard the minimum capacity at DK1-DE/LU as stipulated by the decision of the EU Commission on case AT.40461.

Given the chosen capacity calculation methodology being a C-NTC methodology, the three contributions (CCR Core FB domain, CCR Hansa CNTC CC and CCR Nordic FB domain) are independent inputs into the determination of admissible flows across the CCR Hansa bidding-zone borders. Subsequently there is no need, in capacity calculation, to do simultaneous actions across the CCR Hansa bidding-zone borders. In case CCR Hansa TSOs plan simultaneous activations of remedial actions on both sides of the CCR Hansa bidding-zone border, this will still not lead to the CCR Hansa capacity calculation to be influenced. It will impact the flow-based domain of CCR Nordic or CCR Core and can thereby influence the capacity that can be allocated on the CCR Hansa borders by the market coupling, but the change is realised in the size of the flow-based domains provided to the allocation mechanism.

Til arbejdsbrug/Restricted

4.6.1 Remedial actions to maintain anticipated market outcome on KF CGS

On the KF CGS, wind predictions will be used to predict how much generation is forecasted from the wind farms on KF CGS. This generation is the anticipated market outcome. This anticipated market outcome is used in the capacity calculation on KF CGS. The capacity given will have to be maintained by TSOs, thus the TSOs will use countertrading or redispatching, depending on the situation, to maintain capacity in case the wind forecasts are incorrect. This approach for KF CGS is compliant with the EC decision no. 2020/7948 of 11 November 2020 on the derogation for KF CGS following Article 64 of Regulation (EU) 2019/943.

4.7 Rules for taking into account previously allocated cross-zonal capacity in the day-ahead time frame

The CCR Hansa TSOs shall include the following as already allocated capacity (AAC) to be provided to the Market Operator (MO):

a. Capacity allocated for nominated Physical Transmission Rights (PTRs); and
b. Capacity allocated for cross-zonal exchange of ancillary services, following Electricity Balancing Regulation Articles 40, 41 or 42, except those ancillary services in accordance with Article 22(2)(a) of the CACM Regulation.
c. For KF CGS, AAC^{WIND} is the forecasted wind generation on the OWF(s) based on the relevant CCR Hansa TSOs forecasts.

It is important to consider that the AAC can both be added or subtracted from the cross-border capacity depending on the direction of the AAC.

4.8 Fallback procedure for day-ahead capacity calculation

According to Article 21(3) of the CACM Regulation, the capacity calculation methodology shall include a fallback procedure for any cases where the initial capacity calculation does not lead to any results.

As mentioned in section 4.2, the capacity calculation takes into account three different parts of the grid. This also implies that the fallback procedure for capacity calculation should be applied in cooperation with the adjacent CCRs.

In case the capacity calculation cannot be performed by the CCC, the concerned CCR Hansa TSOs will bilaterally calculate and agree on cross-zonal capacities. CCR Hansa TSOs will individually apply the CCM, and the results will be selected by CCR Hansa TSOs by using the minimum value of adjacent CCR Hansa TSOs of a bidding-zone border. The concerned CCR Hansa TSOs shall submit the capacities to the relevant CCC and to the other CCR Hansa TSOs.

Til arbejdsbrug/Restricted

5 Capacity calculation methodology for the intraday time frame

This chapter describes the target capacity calculation methodology which will be applied for CCR Hansa bidding-zone borders in the intraday time frame.

5.1 Description of the capacity calculation methodology in CCR Hansa

The capacity calculation methodology for the intraday time frame in CCR Hansa is equal to the one described for the DA time frame in section 4.2. This implies that CCR Hansa calculates the capacity for the CCR Hansa interconnectors, while the limitations from AC grids, in the possible extent, are handled by adjacent CCRs. The exception for the border DE/LU-SE4 as set out in chapter 4.2 applies to the intraday time frame accordingly. For CCR Hansa, the target model is reached when XBID is able to handle flow-based constraints.

5.1.1 Capacity limitations originating from adjacent AC grid

The same rules and conditions stated in sections 4.2.2 and 4.2.3 for day-ahead will apply for intraday. It is up to CCR Nordic and CCR Core to represent the flow limitations in the AC grids, while the actual CCR Hansa interconnector capacities are addressed individually within CCR Hansa. Together these three inputs will constitute the limitations on the CCR Hansa interconnectors to be respected in the capacity allocation process.

5.1.2 Further requirements from Article 21(1)(b) of the CACM Regulation

In the following section, the requirements set out in Article 21(1)(b) of the CACM Regulation for a detailed description of the capacity calculation approach are listed and a description is given how these are taken into account.

(ii) rules for avoiding undue discrimination between internal and cross-zonal exchanges to ensure compliance with point 1.7 of Annex I to Regulation (EC) No 714/2009;

Article 14 in the CCM for CCR Hansa states that the methodology for selecting CNEs and the rules for avoiding undue discrimination between internal and cross-zonal exchanges shall follow the rules of the day-ahead section. This is described in section 4.2.4.

(iii) rules for taking into account, where appropriate, previously allocated cross-zonal capacity;

The previously allocated cross-zonal capacity can be subtracted from the actual CCR Hansa interconnector capacity which is described in section 5.6.

(iv) rules on the adjustment of power flows on critical network elements or of cross-zonal capacity due to remedial actions in accordance with Article 25;

In case it would be necessary to adjust the power flow on the CNEs in case the remedial action is situated in the adjacent AC grid, it will be done by adjusting the size of the flow-based domain. The determination of where this adjusted flow-based domain is utilised will be left to the market allocation algorithm optimisation.

taken into account in the CCM, it will be done by adjusting the cross-zonal capacity of the bidding-zone border where the remedial action has effect in either direction, as written in Article 14 in the CCM for CCR Hansa.

Til arbejdsbrug/Restricted

(v) for the flow-based approach, a mathematical description of the calculation of power transfer distribution factors and of the calculation of available margins on critical network elements;
Not applicable, as this will be handled in the flow-based methodologies of CCR Nordic and CCR Core.

(vi) ***for the coordinated net transmission capacity approach, the rules for calculating cross-zonal capacity, including the rules for efficiently sharing the power flow capabilities of critical network elements among different bidding-zone borders;***
As the methodology chosen utilises flow-based domains from the two adjacent CCRs to ensure optimal market efficiency when handling constraint from the AC grids, there is no ex-ante split of capacity on CNEs. This is specified in Article 17 of the CCM for CCR Hansa.

(vii) where the power flows on critical network elements are influenced by cross-zonal power exchanges in different capacity calculation regions, the rules for sharing the power flow capabilities of critical network elements among different capacity calculation regions in order to accommodate these flows.
The use of AHC in CCR Core and CCR Nordic ensures that an economic optimisation determines where capacities are allocated between borders and different capacity calculation regions. This is specified in Article 17 of the CCM for CCR Hansa.

5.2 Methodology for determining the Transmission Reliability Margin
The same methodology for the determination of the reliability margin applies, as described for the day-ahead time frame in section 4.3.

5.3 Methodologies for determining operational security limits, contingencies relevant to capacity calculation and allocation constraints
The methodologies for the intraday time frame for determining operational security limits, contingencies relevant to capacity calculation and allocation constraints are the same as for the day-ahead time frame, see section 4.4.

5.4 Methodology for determining the generation shift keys
The methodology for the intraday time frame for determining the GSKs is the same as for the day-ahead time frame, see section 4.5.

5.5 Methodology for determining remedial actions to be considered in capacity calculation
See section 4.6.

5.6 Rules for taking into account previously allocated cross-zonal capacity in the intraday time frame
In addition to the list specified for the day-ahead in section 4.7, the CCR Hansa TSOs shall also include capacity allocated and nominated to the day-ahead market.

It is important to consider that the AAC can both be added or subtracted from the cross-border capacity depending on the direction of the AAC.

5.7 Intraday reassessment frequency
The frequency of the reassessment of intraday capacity shall be dependent on the availability of input data relevant for capacity calculation, as well as any events impacting the capacity on the cross-zonal lines.

Til arbejdsbrug/Restricted

According to Article 29 of the CACM Regulation, the capacity for the intraday time frame must be calculated by the CCC based on a common grid model (CGM). This can lead to both an increase or a decrease of capacity.

The availability of input data for the common grid model, wind forecasts and measurements of wind generation in relation to Krieger's flak as well as events, e.g. unscheduled outages, influence the cross-zonal capacity and are therefore likely to influence the intraday capacity reassessment frequency.

All TSOs in each capacity calculation region shall ensure that cross-zonal capacity is recalculated within the intraday market time frame based on the latest available information, including unexpected events and taking into consideration efficiency and operational security. The CCC shall ensure that the adjusted capacities are submitted without undue delay to the MCO.

On the 24th of April 2018, ACER made their decision on the All TSOs proposal for intraday cross-zonal gate opening and intraday cross-zonal gate closure time following CACM Regulation Article 59 deciding on a common European intraday cross-zonal gate opening time (IDCZGOT) at 15:00 D-1 CET.

5.8 Fallback procedure for intraday capacity calculation

The fallback procedure for capacity calculation for the intraday time frame is the same as for the day-ahead time frame, see section 4.7.

Til arbejdsbrug/Restricted

6. Common Provisions Applicable to both the Day-Ahead and Intraday Time Frames

6.1 Methodology for the validation of the cross-zonal capacity

The target model of the capacity calculation for CCR Hansa limits the scope of the capacity calculation for CCR Hansa to the interconnections themselves. Therefore, this section only describes the methodology for validating the part of the cross-zonal capacity that is actually calculated by the CCR Hansa CCC.

In accordance with Article 26(1,3), each CCR Hansa TSO shall validate and have the right to reduce cross-zonal capacity relevant to the TSO's bidding-zone borders provided by the CCC. Each CCR Hansa TSO may reduce cross-zonal capacity during the validation of cross-zonal capacity relevant to the CCR Hansa TSO's bidding-zone borders for reasons of operational security. Additionally, each CCR Hansa TSO has the right to propose increases in the cross-zonal capacity. Any increase in capacity following this validation process shall be coordinated by the CCC and commonly agreed upon by the affected CCR Hansa TSOs. The affected CCR Hansa TSO will normally mean the CCR Hansa TSOs directly involved on the specific bidding-zone border in question.

The CCR Hansa TSOs are legally responsible for the cross-zonal capacities. The validation of the interconnection capacity, which is calculated by the CCC, will be performed by each concerned CCR Hansa TSO. The validation of cross-zonal capacity and allocation constraints ensure that the results of the capacity allocation process will respect operational security requirements.

The CCR Hansa TSOs will consider the operational security limits when performing the validation, but may also consider additional grid constraints, grid models and other relevant information. The CCR Hansa TSOs may use, but are not limited to, the tools developed by the CCC for analysis. Thus, the CCR Hansa TSOs might also employ verification tools not available to the CCC. Validation of the results shall include a check of whether the correct data provided by CCR Hansa TSOs was used by the CCC in the capacity calculation process. The CCC of CCR Nordic and CCR Core can, for example, deliver minimum and maximum net positions for each virtual bidding zone, which will allow for CCR Hansa TSOs to compare restrictions imposed on the CCR Hansa interconnectors from the AC grids with the capacity calculation made by the CCR Hansa CCC.

Results from the validation process shall be sent from each CCR Hansa TSO to the CCC of CCR Hansa and at the same time to all CCR Hansa TSOs within a time limit to be agreed upon by all CCR Hansa TSOs. All such decisions from CCR Hansa TSOs on reduction of capacity and proposals for increase of capacity shall include an explanation and justification.

The CCC will coordinate with adjacent CCCs during the capacity calculation and validation process to ensure that the correct input data has been used, and subsequently that the capacities are within a plausible solution space in line with Article 26(4).

Any information on increased or decreased cross-zonal capacity from adjacent CCCs will be provided to the CCR Hansa TSOs to be taken into account during the validation.

If capacities on a given bidding-zone border are regularly corrected by CCR Hansa TSOs, the CCR Hansa TSOs shall jointly evaluate the capacity calculation process and the capacity calculation methodology and investigate how to reduce the need for corrections.

The CCR Hansa CCC shall every three months report all reductions made during the validation of cross-zonal capacity to all CCR Hansa NRAs. The report shall include the location and amount of any reduction

Til arbejdsbrug/Restricted

in cross-zonal capacity and shall give reason for the reductions, following the requirements in CACM Regulation Article 26(5).

According the CACM Article 26(2), the CCM shall include a rule for splitting the correction of cross-zonal capacity between the different bidding zones when using a coordinated NTC methodology. As the CCR Hansa CCM does not include any ex-ante splitting of capacity due to the utilisation of AHC, there will be no need to split a correction of cross-zonal capacity either.

6.2 Monitoring data to the national regulatory authorities

Hansa NRAs may request CCR Hansa TSOs to provide technical and statistical information related to the CCR Hansa DA/ID CCM, as a basis for supervising a non-discriminatory and efficient capacity calculation.

If the aforementioned information is classified as secret or confidential according to national legislation, the CCR Hansa TSOs and the CCR Hansa NRAs will need to ensure that the information is managed in accordance with national legislation.

6.3 Publication of data

Cross-zonal capacities resulting from the CCR Hansa capacity calculation process, as well as information about applied allocation constraints, will be published. The publication of this information may be performed either by the CCR Hansa TSOs or by an entity appointed by the TSOs.

Article 20(1)(a) refers to Article 16(3), which states that CCR Hansa TSOs may reduce cross-zonal capacity during the validation process. The reason for including this reference in Article 20(1)(a) is to emphasize that the cross-zonal capacities to be published should be the final validated capacities that are provided to the relevant NEMOs.

The information about the application of allocation constraints includes information such as what allocation constraint that is applied on what border or bidding zone, and how these allocation constraints are applied. This information is foreseen to be relatively static, and updated whenever there is a change to how or if and allocation constraint is applied.

All data publication must be compliant with confidentiality requirements pursuant to national legislation.

Til arbejdsbrug/Restricted

7. Evaluation of the CCM in light of the objectives of the CACM Regulation

This chapter contains a description of how the draft proposal meets the aims of the CACM Regulation as stated in Article 3.

The CACM Regulation has the objective to ensure optimal use of the transmission infrastructure, operational security and optimising the calculation and allocation of cross-zonal capacity.

The Advanced Hybrid Coupling methodology for CCR Hansa secures optimal use of the transmission capacity as it takes advantage of the flow-based methodologies developed in CCR Nordic and CCR Core in order to represent the limitations in the AC grids, while the actual CCR Hansa interconnector capacities are addressed individually within CCR Hansa. The use of CCR Hansa interconnector capacity and AC grid capacity is fully integrated in this way, thereby providing a fair competition for the scarce capacities in the system and an optimal system use. Indeed, there is no predefined and static split of the CNE capacities, and the flows through CCR Hansa from CCR Core and CCR Nordic are decided based on economic efficiency during the capacity allocation phase.

The CCM treats all borders in CCR Hansa and adjacent CCRs equally and thus provides non-discriminatory access to cross-zonal capacity. It creates a basis for a fair and orderly market and fair and orderly price formation by implementing a simple CCM solution which is integrated with the methodologies of the adjacent CCRs.

The methodology complies with all requirements for operational security and defines methodologies for determining reliability margins, generation shift keys and operational security limits.

The proposal for capacity calculation and allocation in CCR Hansa takes advantage of flow-based capacity calculation for the AC grids while also ensuring full transparency of the calculation of actual CCR Hansa interconnector capacity. This will, in turn, result in a better understanding and increase the transparency and reliability of information on the CCR Hansa borders.

The capacity calculation methodology has no negative consequences on the development of capacity calculation methodologies in CCR Nordic and CCR Core and can evolve dynamically with the development in the future. The methodology therefore does not hinder an efficient long-term operation in CCR Hansa and adjacent CCRs and the development of the transmission system in the Union.

Til arbejdsbrug/Restricted

8. Implementation plan

The Hansa Implementation is structured into the following phases:

- Phase 1 - Appointment of CCCs (already implemented).
- Phase 2 - Operation and calculation of cross-zonal capacities by matching of TTCs/NTCs and AACs, provided by TSOs, and taking into account the validation by the responsible TSO for all bidding zone borders except DE/LU-SE4 and DE/LU-DK2.
- Phase 2b – Same scope as Phase 2 but dedicated to the implementation on the DE/LU-SE4 bidding zone border.
- Phase 2c – Same scope as Phase 2 but dedicated to the implementation on the DE/LU-DK2 bidding zone border.
- Phase 3 – Implementation of Article 4 of this methodology for the DA timeframe and implementation of Article 12 of this methodology for the ID timeframe and usage of CGM in CGMES format.
- ~~Phase 4 – Usage of CGM in CGMES format as used in Hansa ROSC Process as new input data for both DA and ID calculation processes, this step represents a swap of data input for the calculation done in Phase 3.~~

For the bidding zone border DE/LU–DK2, potential future legislation in CACM 2.0 concerning Offshore Bidding Zones might become applicable. Such future setup should be taken into consideration in the capacity calculation methodology and requires more time compared to other borders that are not affected with this regulatory change in terms of implementation. Where such legislation is applicable, any regulatory requirements related to the establishment or consideration of an Offshore Bidding Zone in connection with the Kriegers Flak Combined Grid Solution shall be taken into consideration in the implementation of the solution under this CCM. Where necessary, the CCM shall be amended accordingly to ensure compliance with such obligations.

The implementation plan was streamlined with the merger of Phase 3 and Phase 4 in order to achieve the implementation of the CCR Hansa target model for capacity calculation as required by CACM Regulation earlier and increase the overall implementation as well as cost efficiency of the region. At the finalisation of the present amendment of the CCM, developments in the sphere of the design and structure of the pan-European CGM are ongoing. In addition to that, anticipated recasting of the SO Guideline is expected to govern the requirements for the CGM and potentially introduce changes to processes underlying capacity calculation processes relevant for CCR Hansa. For that, and at the same time considering the ambition to implement the final CCR Hansa milestones for DA and ID CC, a new paragraph was introduced into the DA/ID CCM, which would in turn allow the CCR Hansa TSOs to work towards the final milestones even in the absence of a pan-European CGM, secured trough the availability of suitable and relevant alternatives. Such an early implementation is not expected to lead to redundancies in implementation, as the structures of the final milestones would have to be followed therein, and hence allow for early implementation of a close-to-final target. At the finalisation of the present CCM amendment, however, a sufficient level of certainty on the form and availability of such alternative grid models was not possible to the established. For that, the newly proposed paragraph must remain without details on implementation requirements, but underlines the ambition of the CCR Hansa TSOs to implement close-to-final CCR Hansa targets in the most timely and efficient manner. Hansa TSOs commit to continuously investigate whether there is a possibility in the future that allows to implement for example a regional CGM based capacity calculation process in case this will create a step towards the final milestones and that implementation efforts can be fully used in the target model. This could enable an earlier implementation of an advanced capacity calculation without creating sunk cost at a later stage, as it would rely on the already existing grid models created in Core and Nordic CCRs.

The figure below displays a visualisation of the different phases and interdependencies in the Hansa

Til arbejdsbrug/Restricted

implementation, as well the link to the related articles in the methodology.



Updated version – no Phase 4



Figure 9: Illustration of the dependencies and foreseen implementation deadlines for the DA/ID CCM

Til arbejdsbrug/Restricted



CCR Hansa implementation timeline for DA/ID CCM



* Implementation date is dependent on the confirmation of early implementation possibility and implementation of CGMES format in Core CCR.
** Implementation date of Phase 3 depends on the availability of pan-EU CGM which is uncertain

Til arbejdsbrug/Restricted

Annex 1: Justification of usage and methodology for calculation of allocation constraints in PSE

Allocation constraints in Poland are applied as stipulated in Article 8(2) of the CCM. These constraints reflect the ability of Polish generators to increase generation (potential constraints in export direction) or decrease generation (potential constraints in import direction) subject to technical characteristics of individual generating units as well as the necessity to maintain minimum generation reserves required in the whole Polish power system to ensure secure operation. This is explained further in subsequent parts of this Annex.

Rationale behind implementation of allocation constraints on PSE side

Implementation of allocation constraints as applied by PSE side is related to the fact that under the conditions of integrated scheduling- based market model applied in Poland (also called central dispatching model) responsibility of Polish TSO on system balance is significantly extended comparing to such standard responsibility of TSO in so-called self-dispatch market models. Central dispatching is one of the two dispatching models authorized by EB Regulation. In self-dispatch markets BRPs are themselves supposed to take care about their generating reserves and load following, while TSO ensures them just for dealing with contingencies in the time frame of up to one hour ahead. In a central dispatching model, it is the TSO dispatches generating units taking into account their: operational constraints, transmission constraints and reserve capacity requirements with the aim to balance national generation, demand and cross-border exchanges while ensuring secure operation of the transmission system. When TSO is preparing generation dispatch plans for the operational day, energy and reserves in the central dispatching model are ensured simultaneously (inherent feature of central dispatching systems with accordance to EB Regulation). Results of the wholesale market together with the results of the balancing capacity reserves market serve as a basis for the generation dispatch performed under integrated scheduling process.

In central dispatching model, the above process is realized in an integrated scheduling process run as an single optimization problem called security constrained unit commitment (SCUC – where generation units are being dispatch on and off) and security constrained economic dispatch (SCED – where generation output for all dispatched generation units is determined). Integrated scheduling process starts in the late afternoon of D-1, already well after the day-ahead capacity calculation and SDAC, and continues iteratively by recalculating the future dispatch plans for each particular hour of day D until its real-time execution (new recalculation at least every hour). Within aforementioned integrated scheduling process, generation units connected to the transmission grid are dispatched by PSE with the aim to respect power purchase agreements concluded between market participants on the wholesale market, while minimizing overall costs of dispatch adjustments and balancing energy activation to cover the residual demand (being the part of end users demand not covered by commercial contracts). When doing so, PSE is obliged to respect power system operating conditions, as well as the technical characteristics of generation units both on the level of individual generation units and on the level of power plants. Unit capabilities, considering their inter-temporal limitations (ramping rates), are also considered in this process.

According to the national legislation, PSE is legally obliged to ensure availability of sufficient level of generating reserves for the whole Polish power system in order to safeguard its secure operation in case of contingency, as well as in case of insufficient and ineffective balancing activities performed by market participants in Poland. However, if balancing service providers (generating units) would already sold too much energy in the day-ahead market in form of high exports, they may not be able to provide sufficient upward reserve capacity within the integrated scheduling process as required by national legislation. This conclusion equally applies for the case when market participants import significant amount of energy, as it could result in balancing service providers being unable to provide downward regulation capabilities due to not securing enough generation levels in the day-ahead market. The strength of the imbalance settlement pricing is also important in this process, together with the maturity and the ability of the market participants to maintain balanced portfolios under objectively high RES and demand uncertainties and underdeveloped intraday markets.

This leads to implementation of allocation constraints, being the necessary means to ensure operational security of Polish power system in terms of securing generating capacities for upward or downward regulation, as well as in order to cover the national imbalances in the direction of shortage (i.e. cover the residual demand) and surplus (i.e. manage and regulate down the surplus of power during periods of oversupply). Excluding such a solution and depriving TSOs under central dispatching model from the usage of allocation constraints to set appropriate limits to how much electricity can be imported or exported by

Til arbejdsbrug/Restricted

the system as a whole may lead to insufficient balancing capacity reserves, making the provisions of EB Regulation void, and making it impossible or at least much more difficult to comply with SO Regulation.

It needs to be highlighted that despite implementation of explicit balancing capacity procurement in Poland as per 14 June 2024, and despite maintaining the use of allocation constraints, PSE still has to apply remedial measures at large scale in order to ensure equilibrium between demand and supply in the Polish power system. These measures are mostly the non-market-based curtailment of RES (in case of energy surplus) and emergency exchanges with neighbouring TSOs (in case of energy surplus or shortage). Both aforementioned measures have severe negative consequences, such as difficulties for TSO and DSO dispatching teams to manage hundreds of operational commands issued to dispersed RES facilities in very short time, difficulties of RES facility owners to respond to dispatching commands issued with short notice, as well as depletion of operational reserves of neighbouring TSOs when asked for emergency exchanges, reducing overall European power system resilience. In many instances of time, neighbouring TSOs are unable to provide the requested support.

Balancing market reform executed on 14 June 2024 has significantly improved market price signals, so that balancing responsible parties are better reacting to dynamically changing power system situation. Nonetheless, the observed levels of balancing energy that needs to be activated by PSE under integrated scheduling process is still very high, often exceeding the procured balancing capacity. This implies that the new improved balancing market prices are still unable to convey sufficient incentives for market participants to improve generation and demand planning as BRPs still do not balance their portfolios earlier on more attractive day-ahead and intraday markets. Moreover, new balancing capacity reserves procurement process is still immature and suffers from lack of liquidity, low supply and low competition. Both aforementioned items are a subject of intensive analysis on PSE side with the aim to prepare improvements and increase effectiveness of price signals.

Specification of security limits violated if the allocation constraint is not applied

With regard to constraints used to ensure sufficient operational reserves, if one of interconnected systems suffers from insufficient reserves in case of unexpected outages or unplanned load change (applies to central dispatching model), there may be a sustained deviation from scheduled exchanges of the TSOs in question. These deviations may lead to an imbalance in the whole synchronous area, causing the system frequency to depart from its nominal level. Even if frequency limits are not violated, as a result, deviation activates frequency containment reserves, which will thus not be available for other contingencies, if required as designed. If another contingency materializes, the frequency may in consequence easily go beyond its secure limits with all related negative consequences. This is why such a situation can lead to a breach of operational security limits and must be prevented by keeping necessary reserves within all bidding zones, so that no TSO deviates from its schedule in a sustained way (i.e. more than 15 minutes, within which frequency restoration reserve shall be fully deployed by any given TSO). Finally, the inability to maintain scheduled area balances resulting from insufficient operational reserves will lead to uncontrolled changes in power flows, which may trigger lines overload (i.e. exceeding the thermal limits) and as a consequence can lead to system splitting with different frequencies in each of the subsystems. The above issue affects PSE in a different way from other CCR Hansa TSOs due to reasons explained in the subsequent paragraph.

PSE role in system balancing

PSE directly dispatches all major generating units in Poland taking into account their operational characteristics and transmission constraints in order to cover the load forecasted by PSE, having in mind adequate reserve requirements. To fulfil this task PSE runs the process of operational planning, which begins three years ahead with relevant overhaul (maintenance) coordination and is continued via yearly, monthly and weekly updates to day-ahead SCUD and SCED. The results of this day-ahead market are then updated continuously in intraday time frame up to real time operation.

In a yearly time frame PSE tries to distribute the maintenance overhauls requested by generators along the year in such a way that on average the minimum year ahead generation reserve margin [15] over forecasted demand including already allocated capacities on interconnections is kept on average in each month. The monthly and weekly updates aim to keep a certain reserve margin on each day [16], if possible. This process includes also network maintenance planning, so any constraints coming from the network operation are duly taken into account.

The day-ahead SCUC process aims to achieve a set value of spinning reserve[17] (or quickly activated, in current Polish reality only units in pumped storage plants) margin for each hour of the next day, enabling up and

Til arbejdsbrug/Restricted

down regulation. This includes primary and secondary control power pre-contracted as an ancillary service. The rest of this reserve comes from usage of balancing bids, which are mandatory to be submitted by all centrally dispatched generating units (in practice all units connected to the transmission network and major ones connected to 110 kV, except Combined Heat and Power (CHP) plants as they operate mainly according to heat demand). The remaining generation is taken into account as scheduled by owners, which having in mind its stable character (CHPs, small thermal and hydro) is a workable solution. The only exception from this rule is wind generation, which due to its volatile character is forecasted by PSE. Thus, PSE has the right to use any available centrally dispatched generation in normal operation to balance the system. The negative reserve requirements during low load periods (night hours) are also respected and the potential pumping operation of pumped storage plants is taken into account, if feasible.

The further updates of SCUC/SCED during the operational day take into account any changes happening in the system (forced outages and any limitations of generating units and network elements, load and wind forecast updates, etc.). It allows to keep one hour ahead spinning reserve at the minimum level of 1000 MW, which corresponds to the size of the largest unit in the system.

Determination of allocation constraints in Poland

When determining the allocation constraints, the Polish TSO takes into account the most recent information on the aforementioned technical characteristics of generation units, forecasted power system load as well as minimum reserve margins required in the whole Polish power system to ensure secure operation and forward import/export contracts that need to be respected from previous capacity allocation time frames.

15 The generation reserve margin is regulated by the Polish grid code and currently set at 18% (point 10.2.11(3)). It is subject to change depending on the results of the development of operational planning processes.

16 The generation reserve margin for monthly and weekly coordination is also regulated by the Polish grid code (point 10.2.11(2) and (3)).

17 These values are regulated by the Polish grid code (point 10.2.11(1)) and subject to change.

Til arbejdsbrug/Restricted

Allocation constraints are bidirectional, with independent values for each MTU, and separately for directions of import to Poland and export from Poland.

For each hour, the constraints are calculated according to the below equation:

$$\mathrm{EXPORT}_{constraint} = \mathrm{P}_{CD} - (\mathrm{P}_{NA} + \mathrm{P}_{ER}) + \mathrm{P}_{NCD} - (\mathrm{P}_{L} + \mathrm{P}_{UPres}) \quad (1)$$

$$\mathrm{IMPORT}_{constraint} = \mathrm{P}_{L} - \mathrm{P}_{DOWNres} - \mathrm{P}_{CD_{min}} - \mathrm{P}_{NCD} \quad (2)$$

Where:

P_{CD}	Sum of available generating capacities of centrally dispatched units as declared by generators[18]
$\mathrm{P}_{CD_{min}}$	Sum of technical minima of centrally dispatched generating units in operation
P_{NCD}	Sum of schedules of generating units that are not centrally dispatched, as provided by generators (for weather-dependent intermittent renewable generation: forecasted by PSE)
P_{NA}	Generation not available due to grid constraints (both planned outage and/or anticipated congestions).
P_{ER}	Generation unavailability's adjustment resulting from issues not declared by generators, forecasted by PSE due to exceptional circumstances (e.g. cooling conditions or prolonged overhauls)
P_{L}	Demand forecasted by PSE
P_{UPres}	Minimum reserve for up regulation
$\mathrm{P}_{DOWNres}$	Minimum reserve for down regulation

For illustrative purposes, the process of practical determination of allocation constraints in the framework of day-ahead transfer capacity calculation is illustrated below: figures 1 and 2. The figures illustrate how a forecast of the Polish power balance for each hour of the next day is developed by TSO day ahead in the morning in order to determine reserves in generating capacities available for potential exports and imports, respectively, for day ahead market. For the intraday market, the same method applies mutatis mutandis.

Allocation constraint in export direction is applicable if ΔExport is lower than the sum of transfer capacities on all Polish interconnections in export direction. Allocation constraint in import direction is applicable if ΔImport is lower than the sum of transfer capacities on all Polish interconnections in import direction



1. Sum of available generating capacities of centrally dispatched units as declared by generators, reduced by:
   - 1.1 Generation not available due to grid constraints
   - 1.2 Generation unavailability's adjustment resulting from issues not declared by generators, forecasted by PSE due to exceptional circumstances (e.g. cooling conditions or prolonged overhauls)
2. Sum of schedules of generating units that are not centrally dispatched, as provided by generators (for weather-dependent intermittent renewable generation: forecasted by PSE)
3. Demand forecasted by PSE

[18] Note that generating units which are kept out of the market on the basis of strategic reserve contracts with the TSO are not taken into account in this calculation.

Til arbejdsbrug/Restricted

	4. Minimum necessary reserve for up regulation

Figure 1: Determination of allocation constraints in export direction (generating capacities available for potential exports) in the framework of day-ahead transfer capacity calculation.



1 Sum of technical minima of centrally dispatched generating units in operation

2 Sum of schedules of generating units that are not centrally dispatched, as provided by generators (for weather-dependent intermittent renewable generation: forecasted by PSE)

3 Demand forecasted by PSE, reduced by:

3.1 Minimum necessary reserve for down regulation

Figure 2: Determination of allocation constraints in import direction (reserves in generating capacities available for potential imports) in the framework of day-ahead transfer capacity calculation.

Frequency of re-assessment

Allocation constraints are determined in a continuous process based on the most recent information, for each capacity allocation time frame, from forward till day-ahead and intra-day. In case of day-ahead process, these are calculated in the morning of D-1, resulting in independent values for each MTU, and separately for directions of import to Poland and export from Poland.

Impact of allocation constraints on single day-ahead coupling and single intraday coupling

Allocation constraints in form of allocation constraints as applied by PSE do not diminish the efficiency of day-ahead and intraday market coupling process. Given the need to ensure adequate availability of generation and generation reserves within Polish power system by PSE as TSO acting under central-dispatch market model, imposing constraints on maximum import and export in market coupling process – if necessary – is the most efficient manner of reconciling system security with trading opportunities. This approach results in at least the same level of generating capacities participating in cross border trade as it is the case in self- dispatch market model, where reserves are bought in advance by BRPs or TSO, so they do not participate in cross - border trade, either. Moreover, this allows to avoid competition between the TSO and market participants for generation resources.

It is to be underlined that allocation constraints applied in Poland will not affect the ability of any Hansa country to exchange energy, since these constraints only affect Polish export and/or import. Hence, transit via Poland will be possible in case of allocation constraints applied.

Impact of allocation constraints on adjacent CCRs

Allocation constraints are determined for the whole Polish power system, meaning that they are applicable simultaneously for all CCRs in which PSE has at least one border (i.e. Core, Baltic and Hansa).

It is to be underlined that this solution has been proven as the most efficient application of allocation constraints. Considering allocation constraints separately in each CCR would require PSE to split global allocation constraints into CCR-related sub-values, which would be less efficient than maintaining the global value. Moreover, in the hours when Poland is unable to absorb any more power from outside due to violated

Til arbejdsbrug/Restricted

minimal downward generation requirements, or when Poland is unable to export any more power due to insufficient generation reserves in upward direction, Polish transmission infrastructure still can be – and indeed is - offered for transit, increasing thereby trading opportunities and social welfare in all concerned CCRs.

Time periods for which allocation constraints are applied

As described above, allocation constraints are determined in a continuous process for each capacity allocation time frame, so they are applicable for all MTUs of the respective allocation day.

Why the allocation constraints cannot be efficiently translated into capacities of individual borders offered to the market

Use of capacity allocation constraints aims to ensure economic efficiency of the market coupling mechanism on these interconnectors while meeting the security requirements of electricity supply to customers. If the generation conditions described above were to be reflected in cross-border capacities offered by PSE in form of an appropriate adjustments of border transmission capacities, this would imply that PSE would need to guess the most likely market direction (imports and/or exports on particular interconnectors) and accordingly reduce the cross-zonal capacities in these directions. In the CNTC approach, this would need to be done in a form of ATC reduction per border. However, from the point of view of market participants, due to the inherent uncertainties of market results, such an approach is burdened with the risk of suboptimal splitting of allocation constraints onto individual interconnections – overstated on one interconnection and underestimated on the other, or vice versa. Consequently, application of allocation constraints to tackle the overall Polish balancing constrains at the allocation phase allows for the most efficient use of transmission infrastructure, i.e. fully in line with price differences in individual markets.

Til arbejdsbrug/Restricted

Annex 2: Advanced Hybrid Coupling (AHC) – a Short Explanation

Hybrid coupling stands for the combined use of flow-based and Available Transmission Capacity (ATC) constraints in one single allocation mechanism[1] and is found in the shapes of "Standard" and "Advanced". Though the use of ATC constraints in a flow-based world may not be limited to DC lines only, this explanatory note focuses on this application only, for the sake of clarity.

An ATC constraint sets a limit to a commercial exchange of power between two bidding zones. These ATCs do not physically exist in the grid; indeed, they are the results of scenarios, assumptions, and computations. DC lines between bidding zones are an exception to this statement though: being fully controllable devices, a commercial exchange of 1000 MW between the two bidding zones can be converted directly into a physical flow of exactly 1000 MW on the DC line. In a way, DC lines are the physical reality or representation of an ATC. In short: where an AC grid can be modelled by using the flow-based capacity calculation approach, DC lines interconnecting the AC grids can accurately be modelled by means of ATCs. In order to work in the European market coupling, a hybrid coupling approach is required.

In the next section the interlink between the AC and DC grid is described. Later the difference between Standard and Advanced Hybrid Coupling is explained, followed by a more in-depth description of the capacity calculation and allocation under an Advanced Hybrid Coupling approach.

Interlink between DC connection and AC grid

The power that is traded over the DC link can be produced and consumed anywhere in the AC grid. Therefore, the interaction of the AC grid and the DC grid needs to be modelled.
A DC link is an element, integrated in the AC networks on both sides of the link. Indeed, in the converter stations, where the DC power is transformed into AC power and vice versa, the DC link absorbs its power from, and feeds its power into, the AC grid. From the AC grid point of view, the converter station acts as a source or sink of AC power.

In Figure 11, a DC link is depicted that is interconnecting two AC grids. The white lines represent the AC lines connected to the converter station.

A power flow on the CCR Hansa DC interconnector has a physical impact on the AC grid. If we assume that the power flow on the DC line distributes evenly on the four white AC lines, it implies that 25 % of the flow on the DC line appears as a physical flow on every white AC line.

If during the capacity calculation stage, each of these AC lines has a capacity of 500 MW that can be used by the market, it implies that a maximum DC flow could be allowed of 500 MW / 0.25 = 2000 MW.

If we assume the CCR Hansa DC interconnector has a nominal capacity of 1000 MW, it boils down to a maximum physical flow being induced on the AC lines of 1000 MW * 0.25 = 250 MW. The remaining 250 MW of capacity can then be used for other market transactions, besides the one on the DC line.



Figure 11: Interlink DC line and AC grid

[1] C. Müller, A. Hoffrichter, H. Barrios, A. Schwarz, A. Schnettler: *Integration of HVDC-Links into Flow-Based Market Coupling: Standard Hybrid Market Coupling versus Advanced Hybrid Market Coupling*, CIGRE Symposium Dublin, May/June 2017.

Til arbejdsbrug/Restricted

Hybrid Coupling: Standard and Advanced

As indicated in the introduction, Hybrid Coupling stands for the combined use of flow-based and ATC constraints in one single allocation mechanism. There are two types of hybrid coupling: Standard Hybrid Coupling (SHC) and Advanced Hybrid Coupling (AHC). The difference between those two approaches is highlighted in this section.

Let us consider our example AC transmission line, with a capacity of 500 MW, as introduced above. In a SHC approach, the DC line receives a "priority access" to the AC grid. Simply put: based on the forecasted exchange over DC line (for example: +1000 MW), capacity of the AC transmission (25% * +1000 = +250 MW) line is reserved to facilitate that exchange. Hence based on this forecasted operating point capacity for the AC grid users in the given CCR is reduced in one direction and increased in the opposite ("what is used by one cannot be used by another"). This is different under the AHC approach, where full capacity on the AC transmission line (in both directions) is available to be shared among the grid users in the most optimal way. This is depicted in Figure 12.



Figure 12: Standard Hybrid Coupling and Advanced Hybrid Coupling

The question how the CCR Hansa DC interconnector is modelled under AHC, and how the capacity on the AC transmission line can be shared among the grid users in the most optimal way is touched upon in the following section.

Til arbejdsbrug/Restricted

Capacity calculation and capacity allocation

In the AHC concept, the capacity on the DC line is by default set to its nominal value, which is equal to the full capacity of the DC line. In our example above, it means that the ATC = 1000 MW for the DC line (assuming the Already Allocated Capacity (AAC) to be zero: AAC = 0).

The impact of the DC line on the AC grid is taken into account in the flow-based capacity calculation of the AC areas. The converter station is treated as a so-called virtual bidding area in the flow-based capacity calculation of the AC area: a bidding zone, without production and consumption. In this way, the impact of having import or export of this virtual bidding area (being a commercial exchange over the DC line) on the critical network elements in the AC grid are properly taken into account.

The example from Figure 11 then translates into the situation depicted in Figure 13. The flow on the CCR Hansa DC interconnector has a one- to-one link to the net position (import/export position) of the virtual bidding area, as demonstrated in Figure 14.



Figure 13: AHC

In the example case, the impact of having an export of the virtual bidding area on the critical network element (the AC transmission line that we are focusing on) in the AC grid, amounts to an increase of the line loading of 25 % (and -25 % when the virtual bidding area is in an import position). The so-called power transfer distribution factor (PTDF) in the flow-based methodology equals 0.25. Indeed, the PTDF is a number that translates the amount of export / import to a flow on a critical network element.

In the flow-based methodology, the impact of the virtual bidding area is assessed and quantified in exactly the same way as any other bidding area. Or in other words: when using the AHC, the flow-based methodology specifies the amount of MW available on the different critical network elements, and it determines the amount of MW used when having an import or export from one of the bidding zones and virtual bidding areas. When we zoom in on one of the flow-based areas in Figure 13, we get the image in Figure 15.



Figure 14: Flow on the DC interconnector and the net position of the virtual bidding area

The flow-based constraint of critical network element 1 (CNE1) in Figure 15, may then look as follows:

$$\alpha*NP(A) + \beta*NP(B) + \gamma*NP(C) + 0.25*NP(\text{virtual bidding area}) \leq 500 \text{ MW}$$

Where:

NP: Net position (import or export position of the bidding zone; export being a positive value)
α,β,γ: PTDF factors, translating the net positions of the bidding zones A, B, and C into expected physical flows on CNE1

Of course, the net position of the virtual bidding area cannot exceed the ATC capacity of the DC line.

Til arbejdsbrug/Restricted



Figure 15: Zoom of the flow-based area

It is the flow-based information from the AC areas and the ATC information from the DC lines that is being provided to the allocation mechanism. It is in the allocation mechanism, where the actual import and export positions (and thereby the exchanges on the DC lines) are determined in the most optimal way given the grid restrictions and the order books.

The allocation – being a European-wide optimisation of the matching of demand and supply, given the grid and allocation constraints – allows all market participants to compete over the scarce resource that is the capacity of a line.

This then may result in having a 1000 MW exchange over the DC line, but may also result into an 800 MW exchange on the DC line if this specific outcome leads to a socio-economic optimum in the overall system. Or in other words: although as a result of the capacity calculation stage, the nominal capacity (1000 MW) on the DC line is provided to the allocation mechanism, the European-wide optimal use of the whole connected transmission grid (given the order books provided) can be a solution where not the full capacity on one specific DC line is utilised in all hours.

AC grid limitations restricting the capacity on the DC line

An exceptional situation may arise in which the surrounding local AC grid, where the converter station is located, is facing some operational challenges due to the power transfer of the DC line. When these challenges cannot be handled by the flow-based methodology, for example when it is related to restrictions located in grids at lower voltage levels or voltage or dynamic issues (that are not modelled in the flow-based system), and the flow on the DC line needs to be limited in order to secure a safe grid operation, the CCR Hansa TSO of that AC grid can impose a constraint in the flow-based methodology to do so.

In this example, the ATC capacity of the DC line will remain 1000 MW. The CCR Hansa TSO facing operational issues, can only allow a maximum flow on the DC line of 750 MW to guarantee the safe operation in the AC grid. He can impose this limit, by adding the following constraint to the virtual bidding area in the flow-based domain:
NP(virtual bidding area) ≤ 750 MW

With the ATC capacity of the DC line being 1000 MW, and the export position of the virtual bidding area being restricted to a maximum of 750 MW, the net position of the virtual bidding area can be in between -1000 MW and 750 MW.

In this way, it is not for a technical reason linked to the DC line itself, that the capacity is limited (thereby leaving its ATC untouched), but due to operational challenges in the AC grid, and as such expressed in the flow-based capacity constraints from the AC grid.

Til arbejdsbrug/Restricted

Annex 3: Explanation on a temporary exception for the DA and ID capacity calculation for DE-LU/SE4 (Baltic Cable) to account for the local DSO grid topology on DE side

According to Article 7(3) of the Hansa CCR DA/ID Methodology operational security limits and CNEs of the adjacent AC grids to the Hansa CCR affecting flow interactions over any of the Hansa CCR's interconnectors shall be considered in the flow based calculations of the adjacent CCRs (i.e. Core and Nordic).

However, the topological characteristics of the adjacent AC grid on the DE side in the area of the DE/LU-SE4 interconnector (Baltic Cable), currently are not reflected in the capacity calculation by either the Core or the Hansa CCR. Reason behind is that the AC grid connection between Lübeck and Siems (s. figure below) is characterized by a DSO grid connection running in parallel to the regular 220kV line being operated by TenneT Germany (TTG). As only the TSO grid can be considered for the cross border capacity calculation, any additional capacity for an exchange via Baltic Cable that results from the DSO grid needs to be 'anticipated' by TTG in its capacity calculation process sufficiently in advance. Therefore TTG on one hand is highly relying on accurate data from the responsible DSO of this area whose grid load is extremely sensitive to the infeed of volatile renewable energy while at the same time TTG needs to take precautions to continuously safeguard grid security monitoring forecast changes of the DSO grid.

In order to maximize the offered cross border capacity also for the Hansa border DE/LU-SE4, TTG started reinforcing its own grid topology by upgrading the current 220kV connection between Lübeck and Siems to a 380kV overhead line. The Project is called "Ostküstenleitung" and expected to be commissioned by Q4 2026. In case the project can be realized according to plan, the capacity of the adjacent AC grid of the Core side of the virtual hub for DE/LU-SE4 will be determined solely by the Core flow based capacity calculation utilizing AHC. Thus the capacity calculation for this border can be rendered independently of the local DSO grid topology of this area taking into account both capacity values of Core and Hansa CCR which serves as a prerequisite to comply with Art. 21(2) of this methodology.

However, to also take the necessary precaution accounting for any potential project delays TTG informed all Hansa TSOs and NRAs of Hansa CCR sufficiently in advance of a potential risk of incompliance with Art. 21(2) of Hansa DA/ID CCM that inevitably would arise in case the said grid enforcement project gets delayed past 2026.
To circumvent any potential incompliance TTG requested to amend Art. 7(3) by an explicit exception for the border DE/LU-SE4 while at the same time commits itself to continuously monitor the status of the project and, in case the a delay risk looms to materialize, immediately reports to all NRAs and TSOs of CCR Hansa with undue delay. Furthermore, TTG commits to annually update all mentioned parties on the status of the grid enforcement project in close alignment with Svk and Baltic Cable starting from January 2028.

In case the amended exception shall not be required, TTG shall be held responsible to trigger its removal from the methodology, e.g. in line with an up-following amendment procedure.



Til arbejdsbrug/Restricted