

entso-e sdp meeting

FREQUENCY STABILITY


JOACHIM LEHNER & HANS ABELE / AME

Grimmel, 30th July 2015

AGENDA

- 01 Introduction
- 02 Outline of the topic Frequency Stability
- 03 Example: over-frequency infeed reduction
- 04 Summary & Outlook

01 Introduction



Introduction


DISTINCTION BETWEEN STANDARD INCIDENT AND DEFENSE PLAN

- / Standard incident: incidents ≤ 3 GW
 - / Allowed frequency deviations:
 - / dynamic: $\leq \pm 800$ mHz
 - / stationary: $\leq \pm 180$ mHz
 - / Primary Control designed for standard incident:
 - / Reserve of 3 GW within CE
 - / Full activation within 30s


- / Defence plan: incidents $\gg 3$ GW
 - / Frequency deviations: $47,5 \text{ Hz} \leq f \leq 51,5 \text{ Hz}$
 - / Counter measure:
 - / LFSM-O & LFSM-U
 - / Load shedding

Introduction

DECREASING SYSTEM INERTIA



During normal conditions (interconnected operation)
a low system inertia seems to be acceptable!



Focus lies on System Split scenarios (defense plan)!

Introduction

CHALLENGE SYSTEM SPLIT


- / System Splits (→ *Defense Plan*) arise as a consequence of cascading protection tripping and divide the interconnected system into two or several islanded zones
- / Danger of cascading protection tripping increases in case of high loaded transmission systems with transnational power transits
- / High power transits **before** a system split lead to high power imbalances **after** the system split
- / Parts of the European transmission system are increasingly loaded up to their limits
- / Due to the increasing necessity of transmission needs, the absolute transmission capacities are increased (grid development)
- / In case of a system split the potential power imbalances increase considerably

Introduction

TOPIC MINIMUM INERTIA HAS TO FOCUS ON SYSTEM SPLIT (DEFENCE PLAN)

- / High power transits lead to high power imbalances in case of a system split
- / High power imbalances in combination with (locally) low system inertia lead to high frequency gradients (Rate of Change of Frequency – RoCoF)
- / In case of a system split areas with over- and areas with under-frequency arise

- / Relevance for Frequency Stability:
 - / Frequency has to be kept within the permitted frequency ranges
 - / Rate of Change of Frequency has to be limited

-  Time response of Over- & Under-Frequency actions is of outmost importance!

Introduction

OVER-FREQUENCY-SCENARIO

Over-frequency Island after system split:

/ Load of the Power System & Power Imbalance:

$$/ \quad P_{\text{Load}} = 70 \text{ GW}$$

$$/ \quad \Delta P_{\text{Imbalance}} = 14 \text{ GW} \quad (\Delta P_{\text{Imbalance}} / P_{\text{Load}} = 20\%)$$

/ Infeed related to the load: 120%

/ Non-synchronous share: 95%

/ Conventional share: 25% (conventional power plants operated at 50%, no contribution to over-frequency infeed reduction)

/ Inertia of the Power System:



$$/ \quad T_N = 5 \text{ s}$$

/ Resulting maximum Rate of Change of Frequency (RoCoF) as a result of system split:

$$/ \quad df/dt_{\text{max}} = 2 \text{ Hz/s} \quad \left(\frac{df}{dt} = \frac{\Delta P_{\text{Stör}}}{P_{\text{Netzlast}}} * \frac{f_0}{T_{\text{Netz}}} \quad \text{mit} \quad \frac{df}{dt} = 2 \frac{\text{Hz}}{\text{s}}; f_0 = 50 \text{ Hz} \right)$$



Introduction

OVER-FREQUENCY-SCENARIO (WITH PRC)




Introduction

OVER-FREQUENCY-SCENARIO (WITHOUT PRC)




Introduction

PRIMARY CONTROL NOT RELEVANT FOR SYSTEM SPLITS

- / Available power and time response of primary control designed for standard incident
- / Available power of primary control too small and slow for system splits with
 - / high power imbalances,
 - / low inertia and
 - / high RoCoFs
- / Possible simplifications for the analysis
 - / Primary Control (and Secondary Control) can be neglected
 - / Input parameters of the analysis in per unit
 -  Results valid independent of the size of the islands (after the system split)

02 Outline of the topic Frequency Stability



Outline of the topic Frequency Stability

IMPACTING FACTORS


/ Inertia & Power Imbalance defines the maximum RoCoF:

$$\frac{df}{dt} = \frac{\Delta P_{\text{Stör}}}{P_{\text{Netzlant}}} * \frac{f_0}{T_{\text{Netz}}} \quad \text{mit } f_0=50\text{Hz}$$

/ Operating range of generators (RfG and Operation Handbook):

$$— 47,5 \text{ Hz} \leq f \leq 51,5 \text{ Hz}$$

/ Definition of RoCoF withstand capability?

 Frequency (& RoCoF) has to stay within the limits to

Outline of the topic Frequency Stability

SENSITIVITY MATRIX I

| Over-Frequency | Power Imbalance | System Inertia | RoCoF | Dynamic of Loads | Primary Control | Secondary Control |
|----------------|-----------------|----------------|-------|------------------|-----------------|-------------------|
|----------------|-----------------|----------------|-------|------------------|-----------------|-------------------|





| | | | | | | |
|-----------------------------|---|---|---|---|---|---|
| Normal Operation | ⊘ | ✓ | ✓ | ✓ | ✓ | ✓ |
| System Split (Defence Plan) | ✓ | ✓ | ✓ | ✓ | ✓ | ✓ |








| Under-Frequency | Power Imbalance | System Inertia | RoCoF | Dynamic of Loads | Primary Control | Secondary Control |
|-----------------|-----------------|----------------|-------|------------------|-----------------|-------------------|
|-----------------|-----------------|----------------|-------|------------------|-----------------|-------------------|

| | | | | | | |
|-----------------------------|---|---|---|---|---|---|
| Normal Operation | ⊘ | ✓ | ✓ | ✓ | ✓ | ✓ |
| System Split (Defence Plan) | ✓ | ✓ | ✓ | ✓ | ✓ | ✓ |


Outline of the topic Frequency Stability

SENSITIVITY MATRIX II

| | OF-IR (Delays & Limitations) | | Synthetic Inertia (Delays & Limitations) | |
|-----------------------------|------------------------------|--------------------------|---|---|
| Over-Frequency | Droop Control | Staged Dis-/Reconnection | Pitch Control (WT) | Rotor inertia (WT) |
| Normal Operation | ✓ | ✓ |  |  |
| System Split (Defence Plan) | ✓ | ✓ |  |  |

| | UF-LS (Measurement & breaker delay) | | Synthetic Inertia (Delays & Limitations) | |
|-----------------------------|---|---|---|---|
| Under-Frequency | Fixed thresholds | df/dt | Full Load (WT) | Part Load (WT) |
| Normal Operation |  |  |  |  |
| System Split (Defence Plan) | ✓ |  |  |  |

03 Example: over-frequency infeed reduction




Example: over-frequency infeed reduction


SIMPLIFIED MODELLING OF THE OVER-FREQUENCY LOAD REDUCTION

Simplified behaviour of the Over-Frequency Infeed Reduction (OF-IR) of the generating units:


Step on the
input signal:



Frequency measurement:
Measuring delay
 T_{Meas} [s]





Generating unit:
PT1-Delay
 T_{PT1} [s]



ΔP (Step response)



Example: over-frequency infeed reduction

OVER-FREQUENCY SCENARIO - SENSITIVITIES



Example: over-frequency infeed reduction

OVER-FREQUENCY SCENARIO - SENSITIVITIES



Example: over-frequency infed reduction

NECESSARY TIME RESPONSE OF THE OF-IR


/ RfG:

/ Initial delay $\leq 2s$

/ TAR HS/MS/NS (German dso rules)

/ $T_{an_90\%} \leq 2s$ (Typ 2-Einheiten) bzw.

/ $T_{an_90\%} \leq 5s$ (Typ 1-Einheiten)



/ Comparison to Over-Frequency scenario with $\Delta P_{\text{Imbalance}} / P_{\text{Load}} = 40\%$


/ $T_{an_95\%} \leq 1,6s$

➡ BUT: Only valid if all generating systems accomplish such a fast time response!

Example: over-frequency infeed reduction

TECHNOLOGY-SPECIFIC TIME RESPONSE

04 Summary & Outlook



Summary & Outlook

SUMMARY

- / Distinction between standard incident and defense plan is important
- / Topic minimum inertia has to focus on system split (defence plan)
- / Primary Control not relevant for system splits
- / Recommended simplifications:
 - / Neglecting Primary (and Secondary) Control
 - / Input parameters of the analysis in per unit → results valid independent of the size of the islands (after the system split)
- / Impacting factors of the topic Frequency Stability are identified and a
- / Sensitivity Matrix was introduced

Summary & Outlook

OUTLOOK

- / Hans Abele & Joachim Lehner would like to invite the spd subgroup "Inertia" to Stuttgart in September/October 2015 for a kick-off meeting

- / Proposed Agenda:
 - / Detailed presentation & discussion of the Frequency Stability analysis done so far (Hans Abele & Joachim Lehner)
 - / Further procedure (all)